NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012725-R8**
DATE:	**07/15/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**YKK AP America**
CODE:	**860-1**
REVISION DATE:	**07/28/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. **101 Marietta Street NW, Suite 2100** **Atlanta, GA 30303**	**Precedence®** **Triple Double Hung Vinyl Window** Configuration: X/XX/XX/X Glazing: Insulating Glass (Annealed) Frame: W-2731mm(107.5") H-2019mm(71.5") Sash: W-831mm(32.72") H-1002mm(35.44") DLO: W-745mm(29.34") H-916mm(32.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Class R-PG35 2731 x 2019 (108 x 72)-H** **Design Pressure: ±1676 Pa (35 psf)** **Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)**

Product Tested By: Architectural Testing, Incorporated
Report No: G231-1102-08 (Specimen 2)/W-2117/W-2119/W-2179 /W-2190/W-2194/W-2200
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com