NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI009526.03
DATE: 07/18/2008
CERTIFICATION PROGRAM: Structural
COMPANY: YKK
CODE: 860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. **101 Marietta Street NW, Suite 2100** **Atlanta, GA 30303**	**StyleGuard®** **Fixed Vinyl Window** Configuration: O Glazing: IG-1/8" Heat Strengthened Glass/Laminate-1/8" Annealed Glass/0.090" Solutia Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1270mm(50") H-1981mm(78") DLO: W-1137mm(44.75") H-1848mm(72.75")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/E1996-05 **TAS 201/202/203-94**	**Design Pressure: +50/-50 psf** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated** **Water Penetration Resistance Test Pressure: 359 Pa (7.5 psf)**

Product Tested By: Hurricane Testing Laboratory, LLC
Report No: 0231-0317-06/30/31/32/33/W-2087/W-2138
Expiration Date: **December 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com