

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015091-R1
DATE: 11/22/2020
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 07/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	Precedence® Fixed Vinyl Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-2426mm(95.5") DLO: W-1686mm(66.37") H-2296mm(90.37")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG50 1816 x 2426 (72 x 96)-FW Design Pressure: ±2400 Pa (±50 psf) Canadian Air Infiltration/Exfiltration Level: Fixed Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek
Report No: L2626.01-550-44 R0
Expiration Date: December 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
email: nami@namiinc.com