

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016419
DATE: 11/25/2024
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleGuard® Casement Picture Vinyl Window Configuration: O Glazing: Insulating Glass - 1/8" Annealed Glass/Laminate - 1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1207mm(47.5") H-1562mm(61.5") DLO: W-1067mm(42") H-1422mm(56")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Large Missile Impact Rated

Product Tested By: Intertek, PLC
Report No: N0622.10-550-44/G213-0405-08
Expiration Date: December 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023