

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015869-R2
DATE: 09/05/2023
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 05/30/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Casement Picture Vinyl Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1511mm(59.50") H-2019mm(79.50") DLO: W-1372mm(54") H-1880mm(74")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 1511 x 2019 (60 x 80)-FW Design Pressure: 1680 Pa (35 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, PLC
Report No: N0622.08-550-44/G231-0907-08/W-2179 /W-2190
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com