

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011608-R8
DATE: 07/16/2013
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 06/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Archtop Single Hung Vinyl Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-902mm(35.5") H-2223mm(87.5") Sash: W-832mm(32.75") H-1108mm(43.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 902 x 2223 (36 x 88)-H Design Pressure: 1676 Pa (35 psf) Water Penetration Resistance Test Pressure: 252 Pa (5.25 psf)

Product Tested By: Architectural Testing, Inc.
Report No: C7836.02-550-44/W-2119/W-2128/W-2179 /W-2190/W-2194
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023