# NOTICE OF PRODUCT CERTIFICATION

**CERTIFICATION NO:** NI012075-R8
**DATE:** 08/08/2014
**CERTIFICATION PROGRAM:** Structural
**COMPANY:** YKK AP America
**CODE:** 860-1
**REVISION DATE:** 06/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **YKK AP America, Inc.**<br>**101 Marietta Street NW, Suite 2100**<br>**Atlanta, GA 30303** | **Precedence®**<br>**Single Hung Vinyl Window**<br><br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1334mm(52.5") H-1905mm(75")<br>Sash: W-1260mm(49.63") H-946mm(37.25")<br>DLO: W-1181mm(46.5") H-857mm(33.75") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **AAMA/WDMA/CSA 101/I.S.2/A440-11** | **Class R-PG35 1334 x 1905 (52 x 75)-H**<br>**Design Pressure: 1676 Pa (35 psf)**<br>**Negative Design Pressure: 1676 Pa (35 psf)**<br>**Water Penetration Resistance Test Pressure: 360 pa (7.50 psf)** |

Product Tested By: Architectural Testing Incorporated
Report No: D9107.01-550-47/W-2119/W-2179 /W-2190/W-2194
Expiration Date: **December 31, 2030**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**