

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013196.07-R7  
**DATE:** 05/24/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** YKK AP America  
**CODE:** 860-1  
**REVISION DATE:** 06/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                             | PRODUCT DESCRIPTION                                                                                                                                                                                              |
|------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>YKK AP America, Inc.</b><br><b>101 Marietta Street NW, Suite 2100</b><br><b>Atlanta, GA 30303</b> | <b>StyleView®</b><br><b>Equal Single Hung Vinyl Window</b><br>Configuration: O/X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1003mm(39.5") H-2134mm(83.5")<br>Sash: W-960mm(37.78") H-1052mm(41.43") |

| SPECIFICATION                                                                    | PRODUCT RATING                                                                                                                                            |
|----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> | <b>Class R-PG35 1003 x 2134 (40 x 84)-H</b><br><b>Design Pressure: ±1680 Pa (35 psf)</b><br>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) |

Product Tested By: Architectural Testing, Incorporated  
Report No: F3782.03-550-44/W-1866/W-2075/W-2119/W-2128/W-2179 /W-2190/W-2194  
Expiration Date: **December 31, 2030**

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023