

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013196.26-R7
DATE: 09/21/2023
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 06/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Twin Cottage Single Hung Vinyl Window Configuration: O/XO/X Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.50") H-1816mm(71.50") Sash: W-831mm(32.72") H-1060mm(41.43") DLO: W-745mm(29.34") H-977mm(38.47")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14	Design Pressure: ±2400 Pa (±50 psf)

Product Tested By: Intertek, PLC
Report No: N0622.05-550-44/W-2119/W-2128/W-2179 /W-2190/W-2194
Expiration Date: December 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023