

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013197.04-R9
DATE: 01/26/2018
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 06/17/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Triple Single Hung Vinyl Window Configuration: O/X//O/X//O/X Glazing: Insulating Glass (Annealed) Frame: W-3035mm(119.5") H-1867mm(73.5") Sash: W-924mm(36.38") H-946mm(37.25") DLO: W-745mm(29.34") H-840mm(33.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 3035 x 1867 (120 x 74)-H Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.34 psf)

Product Tested By: Intertek, LLC
Report No: H7026.01-550-44/F3782.03-550-44/W-1917/W-1955/W-2119/W-2128/W-2179 /W-2190/W-2194
Expiration Date: **December 31, 2030**

A handwritten signature in black ink, appearing to be "MD".

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com