

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006735.04-R1
DATE: 01/12/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9000" Tilt Single Hung Fin Frame Vinyl Prime Window Configuration: O/X 2.0" Sill Riser/Modified Weeps Glazing: IG-3/16" Annealed Glass/0.500" Truseal Duraseal Swiggle Spacer System/Laminate-1/8" Annealed Glass/0.090" PVB Interlayer by Solutia/ 1/8" Annealed Glass Frame: W-1346mm(53") H-1880mm(74") Sash: W-1262mm(49.67") H-921mm(36.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-05 ANSI/AAMA/NWDA 101/I.S.2-97 ASTM E1886-02/05/13a/E1996-02/05/14a ASTM F588-04	Class CW-PG100 1346 x 1880 (53 x 74)-H H-C100 1346 x 1880 (53 x 74) H-C100 Design Pressure: ±4800 Pa (100 psf) Wind Zone 4-Missile Level D FER-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-3280-1A/NCTL-210-3130-1/W-1427/W-1931
Expiration Date: **December 31, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023