

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013164-R5
DATE: 05/02/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Shwinco
CODE: 1972-1
REVISION DATE: 04/18/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC 171 Jet Services Way Dothan, AL 36303	Series "9000" Vinyl Single Hung Window w/Flange Configuration: O/X Glazing: IG-Exterior-3/16" Annealed Glass/ Interior-Laminate-1/8" Annealed Glass/0.090" PVB by Eastman/1/8" Annealed Glass Frame: W-1346mm(53") H-2438mm(96") Sash: W-1270mm(50") H-1210mm(47.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 TAS 201/202/203-94 ASTM E1886-05/13a ASTM E1996-05/09/14a	Class LC-PG50 1346 x 2438 (53 x 96)-H Design Pressure: ± 2400 Pa (50 psf) Large Missile Impact Rated Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 360 Pa (7.5 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3975-03/NCTL-210-3975-3A/W-1931
Expiration Date: May 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023