NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI008041-R8**
DATE:	**05/15/2007**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Sun-Tek**
CODE:	**225-1**
REVISION DATE:	**07/22/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. **10303 General Drive** **Orlando, FL 32824**	**Series "SFA" Fixed Aluminum Polycarbonate Dome Skylight** Configuration: O Glazing: Exterior Panel-0.050" Polycarbonate/ Interior Panel-0.030" Polycarbonate Opening: W-572mm(22.5") H-775mm(30.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **AAMA/WDMA/CSA 101/I.S.2/A440-11** **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class R-PG70 572 x 775 (22 x 30)-SKP/RW** **SKP/RW-R70 572 x 775 (22 x 30)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3409-3/W-1683/W-2198
Expiration Date: **March 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com