

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI010803-R5</u>
DATE:	<u>07/25/2011</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>ViWinTech</u>
CODE:	<u>583-1</u>
REVISION DATE:	<u>01/09/2023</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ViWinTech Windows & Doors 2400 Irvin Cobb Drive Paducah, KY 42003	Series "5100 DH Non-Impact HVHZ" Vinyl Tilt Double Hung Window Configuration: X/X Glazing: Insulating Glass (5/32" Annealed) Frame: W-1320mm(52") H-1905mm(75") Sash: W-1251mm(49.25") H-930mm(36.6")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: +60/-60 psf

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14188-1
Expiration Date: August 31, 2026

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com