

Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-870.43	Essential Double Hung 47.5" X 77.7"	101/I.S.2/A440-11	Class LC-PG30; Size Tested 1206mm x 1973mm Type-H; DP +30/-30 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	1206mm	1973mm	G4569.01-201-47-R0	1/26/2017	10/24/2026
407-H-870.44	Essential Double Hung 47.5" X 77.7"	101/I.S.2/A440-08	Class LC-PG30; Size Tested 1206mm x 1973mm Type-H; DP +30/-30 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	1206mm	1973mm	G4569.01-201-47-R0	1/26/2017	10/24/2026
407-H-870.45	Essential Double Hung 35.5" X 77.7"	101/I.S.2/A440-11	Class LC-PG40; Size Tested 901mm x 1973mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	901mm	1973mm	g4565.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.46	Essential Double Hung 35.5" X 77.7"	101/I.S.2/A440-08	Class LC-PG40; Size Tested 901mm x 1973mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	901mm	1973mm	g4565.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.47	Essential Double Hung 41.5" X 65.5"	101/I.S.2/A440-11	Class LC-PG40; Size Tested 1054mm x 1663mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	1054mm	1663mm	g4565.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.48	Essential Double Hung 41.5" X 65.5"	101/I.S.2/A440-08	Class LC-PG40; Size Tested 1054mm x 1663mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	1054mm	1663mm	g4565.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.49	Essential Double Hung 47.5" X 59.5"	101/I.S.2/A440-11	Class LC-PG40; Size Tested 1206mm x 1511mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	1206mm	1511mm	g4565.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.50	Essential Double Hung 47.5" X 59.5"	101/I.S.2/A440-08	Class LC-PG40; Size Tested 1206mm x 1511mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	1206mm	1511mm	g4565.01-201-47-r0	1/26/2017	10/24/2026

Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
407-H-870.51	Essential Double Hung 29.5" X 77.7"	101/I.S.2/A440-11	Class LC-PG40; Size Tested 794mm x 1973mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	794mm	1973mm	g4565.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.52	Essential Double Hung 29.5" X 77.7"	101/I.S.2/A440-08	Class LC-PG40; Size Tested 794mm x 1973mm * Type-H; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	794mm	1973mm	g4565.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.53	Essential Double Hung 35.5" X 59.5"	101/I.S.2/A440-11	Class LC-PG50; Size Tested 901mm x 1511mm * Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	901mm	1511mm	g4563.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.54	Essential Double Hung 35.5" X 59.5"	101/I.S.2/A440-08	Class LC-PG50; Size Tested 901mm x 1511mm * Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	901mm	1511mm	g4563.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.55	Essential Double Hung 47.5" X 47.5"	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1206mm x 1206mm * Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1206mm	1206mm	g4563.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.56	Essential Double Hung 47.5" X 47.5"	101/I.S.2/A440-08	Class LC-PG50; Size Tested 1206mm x 1206mm * Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1206mm	1206mm	g4563.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.57	Essential Double Hung 29.5" X 59.5"	101/I.S.2/A440-11	Class LC-PG50; Size Tested 749mm x 1511mm * Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	749mm	1511mm	g4563.01-201-47-r0	1/26/2017	10/24/2026
407-H-870.58	Essential Double Hung 29.5" X 59.5"	101/I.S.2/A440-08	Class LC-PG50; Size Tested 749mm x 1511mm * Type-H; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	749mm	1511mm	g4563.01-201-47-r0	1/26/2017	10/24/2026

Hallmark® Certificate of Conformance and License (CCL)




AMS, INC.
Administrative Management
Systems, Inc.

Marvin
PO Box 100
401 State Ave N.
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com