NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013312.03-R2**
DATE:	**07/21/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Simpson**
CODE:	**1145-1**
REVISION DATE:	**01/21/2025**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Simpson Door Company **400 Simpson Ave.** **McCleary, WA 98557**	**Series "7901" Opaque** **Wood Panel Outswing Side-Hinged Door** Configuration: X Frame: W-959mm(37.76") H-2073mm(81.61") Panel: W-914mm(36") H-2032mm(80")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E547-00/E330-02 **ASTM E1886-05/E1996-09**	**Design Pressure: ±2640 Pa (55 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0 psf)** **Wind Zone 4 - Missile Level D**

Product Tested By: Construction Consulting Laboratory, International
Report No: CCLI-16-004
Expiration Date: **March 31, 2031**

Administrator's Signature:_____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com