

Roofing Systems, Uplift Resistance

See General Information for Roofing Systems, Uplift Resistance

NCFI POLYURETHANES

R7280

1515 Carter St
PO Box 1528
Mount Airy, NC 27030 USA

SPRAY APPLIED FOAM AND COATING SYSTEMS

1. Uplift Resistance: 160 psf

Deck: — Minimum 15/32-in. thick APA rated plywood sheathing, concrete (pre-cast, panel, poured-in-place, cellular lightweight concrete (LWC), vermiculite, perlite, or gypsum.

Insulation: — Two component, "10-011", "10-013", "10-014", spray applied foamed plastic insulation, 1-in. thick minimum.

Roof Coatings: — Fluid applied base and top coating or gravel surfacing systems, applied in accordance with specified combinations and Classified as Roofing Systems (TGFU).

2. Uplift Resistance: 165 psf

Deck: — Steel, minimum 26 MSG, concrete (pre-cast, panel, poured-in-place, cellular lightweight concrete (LWC), vermiculite, perlite, or gypsum.

Insulation: — Two component, "10-011", "10-013", "10-014", spray applied foamed plastic insulation, 1-in. thick v.

Roof Coatings: — Fluid applied base and top coating or gravel surfacing systems, applied in accordance with specified combinations and Classified as Roofing Systems (TGFU).

3. Uplift Resistance: 90 psf

Deck: — Steel, min 22 MSG.

Insulation (Optional): — Any combination, any thickness of Classified polyisocyanurate, polystyrene, wood fiber or perlite.

Cover Board: — Minimum 1/2-in. thick Classified high density wood fiber board.

Fasteners: — Minimum No. 14 steel screws with 2-7/8 in diameter 26 g galvanized steel plates. A total of 8 screws per 4-ft. by 4-ft. cover board.

Membrane: — Hot-mopped or cold applied built-up roof. Gravel surface removed for recover of existing built-up roof.

Insulation: — Two component, "10-011", spray applied foamed plastic insulation, 1-in. thick minimum.

Roof Coatings: — Fluid applied base and top coating or gravel surfacing systems, applied in accordance with specified combinations and Classified as Roofing Systems (TGFU).

4. Uplift Resistance: 210 psf

Deck: — Plywood, minimum 19/32 in. thick

Membrane: — Uninsulated hot-mopped or cold-applied asphaltic built-up roof. As applicable gravel surfacing removed.

Fasteners: — Annular ring shank nails, 0.105 minimum shank diameter, with 1-7/8 in diameter galvanized steel cap in a 7-in. by 7-in. OC square grid.

Insulation: — Two component, "10-011", spray applied foamed plastic insulation, 1-in. thick minimum.

Roof Coatings: — Fluid applied base and top coating or gravel surfacing systems, applied in accordance with specified combinations and Classified as Roofing Systems (TGFU).

5. Uplift Resistance: 165 psf

Deck: — Steel, minimum 22 MSG, concrete (pre-cast, panel, poured-in-place, cellular lightweight concrete (LWC), vermiculite, perlite, or gypsum.

Sealer: — Two component, "10-011", "10-013", "10-014", spray applied foamed plastic used to seal joints in steel deck, vents and penetrations in steel deck (as applicable) and perimeter.

Reinforcement: — Asphalt coated fiberglass 10 by 20-in. mesh (not UL Classified) laid across steel deck.

Insulation: — Two component, "10-011", "10-013", "10-014", spray applied foamed plastic insulation, 2-in. thick minimum.

Roof Coatings: — Fluid applied base and top coating or gravel surfacing systems, applied in accordance with specified combinations and Classified as Roofing Systems (TGfU).

6. Uplift Resistance: 90 psf

Deck: — Steel, minimum 22 MSG.

Cover Board: — Minimum 1/2-in. thick Classified high density wood fiber board.

Fasteners: — Minimum No. 14 steel screws with 2-3/4 in 26 g galvanized steel plates. A total of 8 fasteners per 4-ft. by 4-ft. cover board.

Insulation: — Two component, "10-011", spray applied foamed plastic insulation, 2-in. thick minimum.

Roof Coatings: — Fluid applied base and top coating or gravel surfacing systems, applied in accordance with specified combinations and Classified as Roofing Systems (TGfU).

Last Updated on 2020-04-30

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."