WINDOW & DOOR MANUFACTURERS ASSOCIATION WDMA

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC. Administrative Management Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413
For more Information visit www.amscert.com
Website: www.kolbewindows.com
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1160.04	Ultra Pushout French Casement, SP, (R&D 23071 Recert 10164)	101/I.S.2/A440-22	Class LC-PG55; Size Tested 1219mm x 1219mm Type-C; DP +55/-60 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	1219mm	1219mm	QCT24-7203.38	2/3/2025	4/29/2025	12/10/2034
413-H-1160.05	Ultra Pushout French Casement, SP, (R&D 23071 Recert 10164)	101/I.S.2/A440-17	Class LC-PG55; Size Tested 1219mm x 1219mm Type-C; DP +55/-60 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	1219mm	1219mm	QCT24-7203.38	2/3/2025	4/29/2025	12/10/2034
413-H-1160.06	Ultra Pushout French Casement, SP, (R&D 23071 Recert 10164)	CSA A440 S1-19	Class LC-PG55; Size Tested 1219mm x 1219mm Type-C; DP +2640/-2880 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	1219mm	1219mm	QCT24-7203.38	2/3/2025	4/29/2025	12/10/2034
413-H-1160.07	Ultra Pushout French Casement, SP, (R&D 23071 Recert 10164)	CSA A440 S1-17	Class LC-PG55; Size Tested 1219mm x 1219mm Type-C; DP +2640/-2880 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	1219mm	1219mm	QCT24-7203.38	2/3/2025	4/29/2025	12/10/2034
413-H-1160.08	Ultra Pushout French Casement, HP, (R&D 23073 Recert 10163)	101/I.S.2/A440-22	Class LC-PG50; Size Tested 1524mm x 1524mm Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	1524mm	1524mm	QCT24-7203.39	4/22/2025	4/29/2025	3/10/2035
413-H-1160.09	Ultra Pushout French Casement, HP, (R&D 23073 Recert 10163)	101/I.S.2/A440-17	Class LC-PG50; Size Tested 1524mm x 1524mm Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf)	1524mm	1524mm	QCT24-7203.39	4/22/2025	4/29/2025	3/10/2035
413-H-1160.10	Ultra Pushout French Casement, HP, (R&D 23073 Recert 10163)	CSA A440 S1-19	Class LC-PG50; Size Tested 1524mm x 1524mm Type-C; DP +2400/-2400 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1524mm	1524mm	QCT24-7203.39	4/22/2025	4/29/2025	3/10/2035
413-H-1160.11	Ultra Pushout French Casement, HP, (R&D 23073 Recert 10163)	CSA A440 S1-17	Class LC-PG50; Size Tested 1524mm x 1524mm Type-C; DP +2400/-2400 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1524mm	1524mm	QCT24-7203.39	4/22/2025	4/29/2025	3/10/2035

Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413
For more Information visit www.amscert.com
Website: www.kolbewindows.com
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com