AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Lippert Components, Inc. dba Kinro Windows
3501 County Road 6 East
Elkhart, IN 46514

Attn: Rob Luter

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG40-1219x1829 (48x72)-FW			
COMPANY AND CODE	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**
Lippert Components, Inc. dba Kinro Windows Code: KIN	9513	9700 PW (PVC)(O)(OG)(INS GL) (ASTM)	FRAME 1219 mm x 1829 mm (4'0" x 6'0")

This Certification will expire **September 10, 2026 (extended from September 10, 2021 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **C1686.01-602-44**

Date of Report: **September 11, 2012**

Evaluated for Certification: **April 16, 2021**

Associated Laboratories, Inc.

Authorized for Certification: **April 16, 2021**

Fenestration and Glazing Industry Alliance

(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)