



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

Lippert Components, Inc. dba Kinro Windows
3501 County Road 6 East
Elkhart, IN 46514

Attn: Rob Luter

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG70-1219x1829 (48x72)-FW Negative Design Pressure = -100 psf			
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
Lippert Components, Inc. dba Kinro Windows Code: KIN	10576	9700 PW (PVC)(O)(OG)(INS GL) (MODIF)(ASTM)	<u>FRAME</u> 1219 mm x 1829 mm (4'0" x 6'0")


This Certification will expire **August 21, 2026 (extended from August 21, 2021 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **C5472.01-602-44; ref. C1958.01-602-44**

Date of Reports: **March 28, 2013; August 24, 2012 (Revised January 21, 2014)**

Evaluated for Certification: **April 16, 2021**


Associated Laboratories, Inc.

Authorized for Certification: **April 16, 2021**



Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)