

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: LUXBAUM 12 FT WOOD EUROPEAN OUTSWING CASEMENT WINDOWS
(FLPA# 16894)

MANUFACTURER: LUXBAUM WINDOWS & DOORS
2400 CENTREPARK WEST DRIVE, SUITE 150
WEST PALM BEACH, FL 33409

To all concerned,

The Luxbaum 12 Ft. European Outswing Casement Window, manufactured by Luxbaum Windows & Doors, is a glazed wood casement window set in a wood frame. The window has been tested per TAS 201, 202, and 203 by Hurricane Test Lab, Inc. with results shown in test reports 0271-0519-05, 0271-0206-02, 0271-0721-02, and 0271-1125-02.

FLPA# 16894-R4 was submitted and approved for the 7th Edition (2020) Florida Building Code.

Technical Documentation:

1. Drawing "CASEMENT WINDOW", signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Hurricane Test Lab, Inc. signed and sealed by Vinu Abraham, PE.
3. Supplemental calculations to support "CASEMENT WINDOW", signed and sealed by Scott Wolters, PE.

I have reviewed FLPA# 16894-R4 and the documentation listed above per the requirements of FAC Rule 61G20-3.007 (1) (f) for Self-Affirmation. The Luxbaum 12 ft. European Outswing Casement Window and this submittal meet all the requirements of the 8th Edition (2023) Florida Building Code, with no changes required.

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
DEC 07 2023

