

**Compliance Statement – T14000 Storefront**  
April 28, 2015

**Evaluator:** Lucas A. Turner, FL PE #58201, 1239 Jabara Ave., North Port, FL

**Florida Product Approval Reference:** FL16992.1

**Product Description:** T14000 Storefront, 4' x 12' max. bay size with reinforcement, 4' x 8' max. bay size with no reinforcement, with design pressures as shown in FPA-T14000-NI.

**Manufacturer:** Tubelite Inc., 3056 Walker Ridge DR. NW Suite G, Walker, Michigan 49544

**Statement of Compliance:** I have reviewed the above-listed product and Florida Product Approval, previously submitted for 2010 Florida Building Code (FBC) compliance, per the requirements of FAC Product Approval Rule Chapter 61G20-3.007(f) for Self-Affirmation.


The new edition of the code, 5<sup>th</sup> Edition (2014) FBC, does not require a material or substantive change of this approved product or its installation. The testing standards and standard dates used in the product testing, as indicated below, are also listed in Chapter 35 of the 5<sup>th</sup> Edition (2014) FBC and are therefore valid and acceptable under the new code.

This product complies with the requirements of the 5<sup>th</sup> Edition (2014) Florida Building Code outside the High Velocity Hurricane Zone.

**Technical Documentation Reviewed:**

- 1) Evaluation Report T14000 Storefront, as approved in 2010 FBC FL16992.1
- 2) Approval drawing FPA-T14000-NI, as approved in 2010 FBC FL16992.1
- 3) Test reports 01-34096.01 and 85303.02-120-32, by Architectural Testing, Inc., and test report 05107L-Center-TH0 by Mid America Testing Laboratory, with testing performed: ASTM E 283-2004, ASTM E 331-2000, AAMA 501.1-2005, and ASTM E330-2002

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Tubelite Inc. or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



27  
4/28/2015  
Lucas A. Turner, P.E.  
FL PE #58201