

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: GOLDBRECHT TH+ SERIES LIFT & SLIDE DOOR
(FLPA# 17112)

MANUFACTURER: GOLDBRECHT USA, INC.
5701 BUCKINGHAM PARKWAY, SUITE G
CULVER CITY, CA 90230

To all concerned,

The TH+ Series Lift & Slide Door, manufactured by Goldbrecht USA, Inc. is a multi-panel glazed aluminum door set in an aluminum frame. The door has been tested per TAS 201, 202, and 203 by Architectural Testing, Inc. with results shown in test reports C5210.01-301-18, C5210.02-301-18, E0244.01-301-18, F8784.01-106-31, H6381.01/02/03-301-18, and I5214.01-106-31.

FLPA# 17112-R5 was submitted and approved for the 6th Edition (2017) Florida Building Code.

Technical Documentation:

1. Drawing "TH+ SERIES LIFT AND SLIDE DOOR" dated 4/17/18 (Rev. D), signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Architectural Testing, Inc. signed and sealed by Tyler Westerling, PE.
3. Supplemental Calculations to support "TH+ Series Lift and Slide Door" drawing, signed and sealed by Scott Wolters, PE.

I have reviewed FLPA# 17112 and the documentation listed above per the requirements of FAC Rule 61G20-3.007 (1) (f) for Product Approval Self-Affirmation. The Goldbrecht TH+ Series Lift & Slide Door and this submittal meet all of the requirements of the 7th Edition (2020) Florida Building Code, with no changes required.

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
DEC 09 2020



SPECIALIZING IN IMPACT RESISTANT CURTAIN WALLS, STOREFRONTS, & WINDOWS