

Compliance Statement FL17403
September 21, 2023

Evaluator: Lucas A. Turner, FL PE #58201, 2428 Old Natchez Trc. Trl., Camden, TN

Florida Product Approval Reference: FL17403

Product Description: 5XPT Aluminum Sliding Glass Door, OX


Manufacturer: EFCO Corporation, 1000 County Road, Monett, Missouri

Statement of Compliance: I have reviewed the above-listed product and Florida Product Approval, previously approved for 7th Edition (2020) Florida Building Code (FBC) compliance, per the requirements of FAC Product Approval Rule Chapter 61G20-3.007(f) for Self-Affirmation.

The new edition of the code, 8th Edition (2023) FBC, does not require a material or substantive change of this approved product or its testing. The testing standard and standard date listed in this approval, AAMA/WDMA/CSA 101/I.S.2/A440-08, is also listed in the 8th Edition (2023) FBC and is therefore valid and acceptable under the new code.

This product complies with the requirements of the 8th Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in EFCO Corporation, or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2023.09.25
11:13:24 -05'00'

9/21/2023
Lucas A. Turner, P.E.
FL PE #58201