

January 16, 2018

Mr. Dan Nagy
Eurostyle Impact Windows and Doors
217 NW 4th Avenue
Hallandale Beach, FL 33009

Re: Product Approval No. FL16339.1 (R2) Series 4500 Vinyl Fixed Impact Window
Product Approval No. FL16340.1 (R2) Series 4500 Vinyl Impact Tilt-Turn Window
Product Approval No. FL16341.1 (R1) Series 4500 Vinyl Impact Tilt-Slide Door
Product Approval No. FL17030.1 (R1) Series 4500 Vinyl Impact French Door (8'-0")
Product Approval No. FL20855.1 (R1) Series 700 Vinyl Impact Single Hung Window

ENGINEER'S STATEMENT OF CODE COMPLIANCE

I have evaluated the above-referenced products and find them to conform to the applicable sections of the Florida Building Code, 6th Edition (2017) including, but not limited to Section 1709.5 "Exterior Window and Door Assemblies," and Section 2615 "High-Velocity Hurricane Zones – Plastics."

No change has been made to the reference standards that affect the above-referenced products, including the test protocols.

When used in areas requiring windborne debris protection, the products comply with Section 1609.1.2 "Protection of Openings", and Section 1626 "HVHZ Impact Tests for Windborne Debris"; hurricane shutters are not required.

Please do not hesitate to contact me if you have any questions or comments, or require further information.

Sincerely,

Emma T. Mellinger, P.E.
FL PE# 50049
January 16, 2018

