

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: JS SERIES UNCLIPPED WOOD MULLIONS
(FLPA# 21583-R3)

MANUFACTURER: MQ WINDOW AND DOOR
1855 GRIFFIN ROAD, SUITE A-274
DANIA BEACH, FL 33412

To all concerned,

The MQ JS Unclipped Wood Mullion, manufactured by MQ Window and Door, is a steel reinforced wood mullion that can be installed horizontally or vertically. The mullion has been tested per TAS 201, 202, and 203 by Hurricane Test Lab, Inc. with results shown in test reports G118-1103-98 and G118-1006-98, and by Intertek with results shown in test report 101861406COQ-002.

FLPA# 21583-R2 was submitted for the 7th Edition (2020) Florida Building Code.

Technical Documentation:

1. Drawing "MQJS-MULL", signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Hurricane Test Lab, Inc. signed and sealed by Vinu Abraham, PE.
3. Test Report listed above by Intertek, signed and sealed by Rick Curkeet, PE.
4. Supplemental calculations to support "MQJS-MULL", signed and sealed by Scott Wolters, PE.

I have reviewed this submittal and the documentation listed above per the requirements of FAC Chapter 61G20-3.007 (1) (f) for Self-Affirmation. This product and this submittal meet all the requirements of the 8th Edition (2023) Florida Building Code, including the HVHZ provisions, with no changes required.

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
JUL 19 2023

