

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: ABRAMS AAP-100 (RAINSOON) WALL CLADDING SYSTEM (LMI & SMI)
ABRAMS AAP-700 (MALE/FEMALE) WALL CLADDING SYSTEM
ABRAMS AAP-900 (WET SEAL) WALL CLADDING SYSTEM
ABRAMS AAP-950 (DRY JOINT) WALL CLADDING SYSTEM
(FLPA# 32362-R3)

MANUFACTURER: ABRAMS ARCHITECTURAL PRODUCTS
7260 DELTA CIRCLE
AUSTELL, GA 30166

To all concerned,

The AAP-100 (Rainscreen), AAP-700 (Male/Female), AAP-900 (Wet Seal), and AAP-950 (Dry Joint) Wall Cladding Systems, manufactured by Abrams Architectural Products, are Composite Metal Panel Systems consisting of 4mm Alucobond panels or 1/8" aluminum plate panels (3003-H14 Alloy), with extruded aluminum framing, fastened to 5/8" CDX plywood over 16 Ga. metal stud framing (min). The systems have been tested per TAS 201, 202, and 203 by Intertek B&C, with results shown in test reports K3255.01-550-18, K3255.03-550-18, K3255.06-550-18, and K3255.07-550-18.

FLPA# 32362-R2 was submitted and approved for the 7th Edition (2020) Florida Building Code.

Technical Documentation:


1. Drawings "AAP-100LMI", "AAP-100" (Rev. 1), "AAP-700" (Rev. 1), "AAP-900" (Rev. 1), and "AAP-950" (Rev. 1), dated 6/4/22, signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Architectural Testing, Inc. signed and sealed by Tanya Dolby, PE.
3. Supplemental Calculations to support drawings listed above, signed and sealed by Scott Wolters, PE.

I have reviewed FLPA# 32362-R2 and the documentation listed above per the requirements of the FAC Chapter 61G20-3.007 (1) (f) for Self-Affirmation. The AAP-100 (Rainscreen), AAP-700 (Male/Female), AAP-900 (Wet Seal), and AAP-950 (Dry Joint) Wall Cladding Systems and this submittal meet all of the requirements of the 8th Edition (2023) Florida Building Code, including the HVHZ provisions, with no changes required.

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354



AUG 01 2023

SPECIALIZING IN IMPACT RESISTANT CURTAIN WALLS, STOREFRONTS, & WINDOWS