

**Compliance Statement FL38573**  
September 25, 2023

**Evaluator:** Lucas A. Turner, FL PE #58201, 2428 Old Natchez Trc. Trl., Camden, TN

**Florida Product Approval Reference:** FL38573

**Product Description:** Series 590X Outswing Casement Window


**Manufacturer:** EFCO Corporation, 1000 County Road, Monett, Missouri

**Statement of Compliance:** I have reviewed the above-listed product and Florida Product Approval, previously approved for 7<sup>th</sup> Edition (2020) Florida Building Code (FBC) compliance, per the requirements of FAC Product Approval Rule Chapter 61G20-3.007(f) for Self-Affirmation.

The new edition of the code, 8<sup>th</sup> Edition (2023) FBC, does not require a material or substantive change of this approved product or its testing. The testing standard and standard date listed in this approval, AAMA/WDMA/CSA 101/I.S.2/A440-17, is also listed in the 8<sup>th</sup> Edition (2023) FBC and is therefore valid and acceptable under the new code.

This product complies with the requirements of the 8<sup>th</sup> Edition (2023) Florida Building Code including the High Velocity Hurricane Zone.

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in EFCO Corporation, or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner  
2023.09.25  
11:11:24 -05'00'

9/25/2023  
Lucas A. Turner, P.E.  
FL PE #58201