

WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97th Road N
West Palm Beach, FL 33412
Ph/Fx: (561) 225-1982

PRODUCT EVALUATION

PRODUCT: ABRAMS AAP-N'VEE WALL CLADDING SYSTEM
(FLPA# 41860-R1)

MANUFACTURER: ABRAMS ARCHITECTURAL PRODUCTS
7260 DELTA CIRCLE
AUSTELL, GA 30166

To all concerned,

The AAP-N'VEE Wall Cladding System, manufactured by Abrams Architectural Products, is fabricated from 6" and 8" extruded aluminum (6063-T5 min) panels. The panels are directly fastened to 5/8" CDX plywood over 16 Ga. metal stud framing (min). The system has been tested per TAS 201, 202, and 203 by Intertek B&C, with results shown in test report N9219.01-550-18.

FLPA# 41860 was submitted and approved for the 7th Edition (2020) Florida Building Code.

Technical Documentation:


1. Drawing "AAP-NVE", dated 12/30/22, signed and sealed by Scott Wolters, PE.
2. Test Report listed above by Architectural Testing, Inc. signed and sealed by Tanya Dolby, PE.
3. Supplemental Calculations to support "AAP-NVE", signed and sealed by Scott Wolters, PE.

I have reviewed FLPA# 41860 and the documentation listed above per the requirements of the FAC Chapter 61G20-3.007 (1) (f) for Self-Affirmation. The AAP-N'VEE Wall Cladding System and this submittal meet all of the requirements of the 8th Edition (2023) Florida Building Code, including the HVHZ provisions, with no changes required.

If you have any questions or need more information concerning this approval please contact me.

Thank you,


Scott Wolters
FL PE# 62354
AUG 01 2023



SPECIALIZING IN IMPACT RESISTANT CURTAINWALLS, STOREFRONTS, & WINDOWS