

Evaluation Report 526-DRY-LM
September 29, 2023

Product Description: Series S526 Storefront System, Dry Glazed HVHZ Impact

Manufacturer: EFCO Corporation, 1000 County Road, Monett, Missouri

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Installation drawing 526-DRY-LM, rev. A, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Report CCLI #12-145, from Construction Consulting Laboratory, International, Carrollton, TX with testing performed with equivalency to: TAS-201/202/203-94, AAMA 501-15
- 4) Supplemental Calculations to support 526-DRY-LM, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to installation drawing 526-DRY-LM.

Limitations of Use: This product:

- May be used in the configurations and sizes with glazing as indicated in 526-DRY-LM.
- Is large and small missile impact-resistant and does not require the use of impact protective devices
- May be used in the High Velocity Hurricane Zone
- Requires Kuraray Sentryglas per current Miami-Dade NOA. I have evaluated this interlayer material and find that it complies with the requirements of the 8th Ed. (2023) Florida Building Code for use in this product.
- Requires aluminum framing as indicated in 526-DRY-LM

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in EFCO or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



9/29/2023
Lucas A. Turner, P.E.
FL PE #58201