

Evaluation Report 2700-CI-NI

June 25, 2024

Product Description: Series 2700 Casement Inswing Window, Non-Impact
with Butt Hinges and Cam Locks

Manufacturer: EFCO, 1000 County Road, Monett, Missouri

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Installation drawing 2700-CI-NI, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Report I7164.01-801-47-r0, from Intertek, with testing performed with equivalency to: AAMA/WDMA/CSA 101/I.S.2/A440-17
- 4) Supplemental Calculations to support 2700-CI-NI, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to installation drawing 2700-CI-NI.

Limitations of Use: This product:

- May be used in the configuration and sizes with glazing as indicated in 2700-CI-NI.
- Is non-impact and requires the use of impact protective devices in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires 6063-T6 aluminum framing as indicated in 2700-CI-NI

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in EFCO or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner

2024.06.25

10:58:15

-05'00'

6/25/2024

Lucas A. Turner, P.E.
FL PE #58201