

Evaluation Report I-NX3800

February 26, 2015

Product Description: Series NX3800 Aluminum Fixed Window, Non-Impact, max. unit size of 60" x 99", Design Pressure +/-80 PSF

Manufacturer: Traco, a division of Kawneer, 71 Progress Ave., Cranberry Township, PA

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 5th Edition (2014) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

- 1) This report, prepared by Lucas A. Turner, P.E., at 1239 Jabara Ave., North Port, FL
- 2) Approval drawing I-NX3800, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Report 88210.01-501-44 from Architectural Testing, Inc., in Springdale, PA
 - a. Testing Performed: AAMA/WDMA/CSA 101/I.S.2/A440-08
- 4) Supplemental Calculations to support I-NX3800, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document I-NX3800.

Limitations of Use: This product:

- May be used up to sizes indicated above in Product Description as indicated in I-NX3800, with glass types, design pressures, and max. glass daylight sizes as shown in I-NX3800
- Is non-impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires 6063-T6 aluminum extrusions per I-NX3800

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Traco, a division of Kawneer, or Kawneer, or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



22
2/26/2015
Lucas A. Turner, P.E.
FL PE #58201