

Evaluation Report Clearwall
October 13, 2020

Product Description: Clearwall Curtain Wall System, 2-1/2" Wide

Manufacturer: Kawneer Company, 555 Guthridge Court, Norcross, Georgia, 30092

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule 61G20-3.005 (4). This product complies with the requirements of the 7th Edition (2020) Florida Building Code for use outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing T172901, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports 0049-0210-10A from Hurricane Test Laboratory in Riviera Beach, FL, and QCT10-1692.01 from Quast Consulting and Testing, Mosinee, WI
 - a. Testing Performed with equivalency to: ASTM E283-04(12), ASTM E330-02, ASTM E331-00(09), AAMA 501.1-15, and AAMA 501.5-15
- 4) Supplemental Calculations to support T172901, signed and sealed by Lucas A. Turner, P.E.


Installation: Units must be installed according to approval document T172901.

Limitations of Use: This product:

- May be used up to sizes indicated in T172901, with mullion types, glass and glazing types, design pressures, and max. daylight sizes as shown in T172901
- Is Non-Impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires 6063-T6 aluminum extrusions per T172901

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Kawneer Company, or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.

Lucas Turner
2020.10.13
16:57:30
-05'00'



LT
10/13/2020
Lucas A. Turner, P.E.
FL PE #58201