

Evaluation Report 705/755 AW
November 17, 2016

Product Description: Series 705/755 PVC Awning Window

Manufacturer: Atrium Windows & Doors, Dallas, TX and Welcome, NC

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 5th Edition (2014) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

- 1) This report, prepared by Lucas A. Turner, P.E., at 1239 Jabara Ave., North Port, FL
- 2) Approval drawing 'ADW-00 700 AW ASSY' signed and sealed by Lucas A. Turner, PE
- 3) Test Reports NCTL-110-19440-1, from National Certified Testing Laboratories, York, PA, and E1448.01-801-47, from Intertek/ATI, Southlake, TX
 - a. Testing Performed: AAMA/WDMA/CSA 101/I.S.2/A440-08/11
- 4) Supplemental Calculations to support ADW-00 700 AW ASSY, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document ADW-00 700 AW ASSY.

Limitations of Use: This product:

- May be used up to sizes and design pressures as shown in ADW-00 700 AW ASSY
- Is nonimpact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Atrium Windows & Doors or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.

Lucas A.
Turner
2016-11-17
16:23+19:00



LT
11/17/2016
Lucas A. Turner, P.E.
FL PE #58201