

Monta Consulting & Design

of WMR and Associates, LLC

Northpoint II
1035 Greenwood Blvd, Suite 173
Lake Mary, FL 32746

Phone (407) 681-1917
Certificate of Authorization # 9177
montaconsulting.com

Structural Engineering, Truss Engineering, Third Party Inspection, Forensic Study, Project Management
Residential Design and BIM Modeling for Homebuilders

ENGINEERING EVALUATION REPORT

MANUFACTURER: Pro-Crete Materials Corporation
1617 Division Avenue
Orlando, FL 32805

PRODUCT LINE: **8" and 12" precast lintel**
8" prestressed lintel

PRODUCT DESCRIPTION:
8" and 12" precast and prestressed concrete lintels.

COMPLIANCE:
The above-mentioned product(s) has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3. To the best of my knowledge, the product(s) complies with the Florida Building Code 8th Edition (2023) Building, sections 1901.2 and 2107; and with Florida Building Code 8th Edition (2023) Residential, sections R402.2 and R606.

SUPPORTING TECHNICAL DOCUMENTATION:
Design drawings (Job# 18696), prepared by Monta Consulting & Design from information supplied by Pro-Crete Materials Corporation, signed and sealed by Thuy H. Huynh, PE.

LIMITATIONS AND CONDITIONS OF USE:

- a) Support on wood – Lintel shall not be support on wood girders or other form of wood construction.
- b) Construction loads – Do not apply construction loads that exceed the safe superimposed load-carrying capacity of the masonry and temporary support, if used.
- c) Impact resistance – Lintels apply to the design or construction of masonry for buildings, parts of buildings, or other structures, if the project is located in areas where the ultimate wind speed exceeds 160 mph, exposure B shall be filled solid with grout.

INSTALLATION:
Installation shall be in accordance with the installation instructions, prepared by Monta Consulting & Design, and with the most stringent of manufacturer requirements and the FBC 8th Edition (2023).


Monta Consulting & Design

of WMR and Associates, LLC

CERTIFICATION OF INDEPENDENCE:

I do not have nor will I seek to acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. I do not have nor will I seek to acquire financial interest in any other entity involved in the approval process for which this report is being issued.

Conclusions are limited to the items indicated for this project only. Further, it is the client's responsibility to contact Monta Consulting & Design, if as-built conditions change from the time of our review.



Thuy H. Huynh, P.E.
Florida Lic. No. 60122
11/2/2023