

Evaluation Report FPA-82000-SH
December 15, 2025

Product Description: Series 82000 PVC Single Hung Window, Non-Impact

Manufacturer: Tafco Corporation, 1953 North 17th Ave., Melrose Park, Illinois 60160

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005. This product complies with the requirements of the 8th Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trace Trail, Camden, TN
- 2) Approval drawing FPA-82000-SH, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports H0399.02-109-44, from Intertek/ATI, York, PA
 - a. Testing Performed: AAMA/WDMA/CSA 101/I.S.2/A440-11
- 4) Supplemental Calculations to support FPA-82000-SH, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document FPA-82000-SH.

Limitations of Use: This product:

- May be used in O/X configuration in up to 40"x63" size, with minimum glazing and max. glass daylight sizes as shown in FPA-82000-SH
- Achieves design pressures of +/-15 psf with insulating glass or single glass
- Is non-impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires Huazhijie Plastics Building Materials Co. Ltd. (ZHP-1) PVC extrusions, with current extruder listing as an AAMA Certified Profile Licensee under AAMA 303

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Tafco Corporation or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2025.12.15
17:40:08 -06'00'

12/15/2025
Lucas A. Turner, P.E.
FL PE #58201