

Evaluation Report FPA-Rogue-NI
January 31, 2024

Product Description: 1-3/4" Inswing Wood Door, Non-Impact, Single or Double, with or without Transom and/or Sidelites

Manufacturer: Rogue Valley Door, 123 NE Beacon Dr., Grants Pass, Oregon

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code for use outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc. Trl., Camden, TN
- 2) Installation drawing FPA-Rogue-NI, rev. A, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports TEL 01740160/161/162/189, from Testing Evaluation Laboratories, with testing performed with equivalency to: AAMA/WDMA/CSA 101/I.S.2/A440-08 (tested with water spray only, at zero pressure differential during water test)
- 4) Supplemental Calculations to support FPA-Rogue-NI, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to installation drawing FPA-Rogue-NI.

Limitations of Use: This product:

- May be used in the configurations and product sizes as indicated in FPA-Rogue-NI
- Is non-impact and requires the use of impact protective devices in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires construction with pine wood min. with $G \geq 0.42$

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Rogue Valley Door or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



Lucas Turner
2024.01.31
16:59:00 -06'00'

1/31/2024
Lucas A. Turner, P.E.
FL PE #58201