



LIMITATIONS


- 1) Fire Classification is not within the scope of this evaluation.
- 2) Installation of the evaluated products shall comply with FBC Section 1507.3, FRSA/TRI *Florida High Wind Concrete and Clay Roof Tile Installation Manual*, Sixth Edition and the manufacturer's published application instructions. Installations in the HVHZ shall comply with RAS 120. Where discrepancies exist between these sources, the more restrictive detail shall prevail.
- 3) Design wind load requirements shall be conducted in accordance with FBC Section 1609.5.3 in the non-HVHZ and RAS 127 in the HVHZ, using a moment based system.
- 4) All tiles shall bear the imprint or indelible label "El Trebol, Made in Colombia".
- 5) In the HVHZ, a static field uplift test shall be conducted in accordance with TAS 106.
- 6) All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.

COMPLIANCE STATEMENT

The products evaluated herein by Jose J. Roldan P.E. have demonstrated compliance with the Florida Building Code, 8th Edition (2023) including High-Velocity Hurricane Zones (HVHZ) as evidenced in the referenced documents submitted by the named manufacturer.

Jose J Roldan, State of Florida, Professional Engineer,
License No. 61827
This item has been digitally signed and sealed by Jose
J Roldan P.E.
Printed copies of this document are not considered
signed and sealed and the signature must be verified
on any electronic copies.

JOSE J ROLDAN



Jose J. Roldan P.E
P.E. 61827

CERTIFICATION OF INDEPENDENCE

A+ Engineering Testing Lab LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

A+ Engineering Testing Lab LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Jose J. Roldan P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Jose J. Roldan P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT

Page 3 of 3