


SHEET LEGEND	
Sheet: 1 of 2	PRIMARY
Sheet: 2 of 2	Revision History


FLORIDA PRODUCT APPROVAL:
- FL 10196

CATEGORY:
BIFOLD DOOR


UNIT TYPE:
ELBFLD, NBFELD, VNBFLD




HEADER



SILL



JAMB, OPERATOR



JAMB, STATIONARY

NOTES:

- FOR GENERAL SPECIFICATIONS, REFER TO DOC 00003952
- FOR ELEVATIONS AND SPACING INFO, REFER TO DOC 00127402
- FOR SIZE AND DP LIMITATIONS, REFER TO DOCS:
 - INFINITY 00123322
 - ELEVATE 00126258
- THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING AND SEALING INSTRUCTIONS, REFER TO INSTALLATION INSTRUCTIONS.
- INSTALLATION METHODS:
 - ROUGH OPENING
 - MAX. OF 1/2" GAP AT POINTS OF ATTACHMENT
 - SHIMS
 - PLACE SHIMS WITHIN 4"-6" OF EACH CORNER AND AT EACH THROUGH JAMB LOCATION
 - ALL OTHER SHIMS MUST BE PLACED A MAX OF 15" APART
 - SILL
 - PLACE THREE CONTINUOUS 3/8" BEADS OF ASTM C920 GRADE NS CLASS 25 SEALANT TO BOTTOM OF SILL/FRAMING
 - APPLY SILL INSTALLATION SCREWS THROUGH SILL INSTALLATION HOLES INTO FLOOR
 - JAMBS
 - USE SUPPLIED SCREWS AT EACH PRE-DRILLED LOCATION

e. HEADER

- APPLY WASHER HEAD SCREWS THROUGH ALUMINUM TRACK
 - APPLY INSTALLATION SCREWS THROUGH PRE-DRILLED HOLES IN WOOD HEADER THROUGH LINER AND INTO FRAMING
- IF CHEMICALLY TREATED LUMBER IS USED FOR BUCK MATERIAL, FASTENERS INTO BUCK MUST BE MIN OF .090 OZ/ FT^2 ZINC HOT DIPPED GALVANIZED STEEL TYPE 304 OR 316
 - MINIMUM SCREW EMBEDMENT DEPTH: 1- 1/4"
 - MINIMUM SCREW EMBEDMENT DEPTH: 3/4"
 - MINIMUM EDGE DISTANCE: 5/8"
 - FOR THE SCREW LOCATION, REFER TO DOC 00125937
 - GLASS COMPLIES WITH ASTM E1300

CONFIGURATION	MAX SIZE	MAX PANEL SIZE	DP RATING
O	39-9/32" X 95-1/2"	37-3/8" X 90-35/64"	+30/-30
1L, 1R	39-9/32" X 95-1/2"	37-1/8" X 90-35/64"	+30/-30
2L, 2R, 1L1R RH, 1L1R LH	76-59/64" X 95-1/2"	37-1/8" X 90-35/64"	+30/-30
3L, 3R, 2L1R, 1L2R	114-5/32" X 95-1/2"	37-1/8" X 90-35/64"	+30/-30
4L, 4R, 3L1R, 1L3R, 2L2R	151-23/32" X 95-1/2"	37-1/8" X 90-35/64"	+30/-30
5L, 5R, 4L14, 1L4R	189" X 95-1/2"	37-1/8" X 90-35/64"	+30/-30
6L, 6R, 5L1R, 1L5R, 3L3R RH, 3L3R LH	226-15/32" X 95-1/2"	37-1/8" X 90-35/64"	+30/-30
7L, 7R, 6L1R, 1L6R	263-27/32" X 95-1/2"	37-1/8" X 90-35/64"	+30/-30

7	00014060	STATIONARY PANEL CLIP
6	NA	ASTM C920 GRADE NS CLASS 25 SEALANT
5	NA	SHIM
4	00003228	#8-15 X 2.500" TYPE A/TF, 2/3 THREAD
3	00003285	#8-18X1.500" TYPE A/ AB, FULL THREAD
2	00003264	#8-18 X 3.000" TYPE AB, FULL THREAD
1	00101249	1/4 X 3 1/8" WASHER HEAD SCREW

ITEM	DWG NO	DESCRIPTION
------	--------	-------------

PARTS LIST

MARVIN  **RESEARCH & DEVELOPMENT**

COLLECTION: ELEVATE, INFINITY, VIVID

DWG TYPE: INSTALLATION
DESCRIPTION: INSTALLATION METHODS, THROUGH JAMB

SHEET NAME: PRIMARY (1 OF 2)

CHK: CLE	SIZE: B	CLASS: MISC	DWG NO: 00127403	REV: 3
APP: JHS	SCALE: 1 : 2	DATE: 1/24/2021	DWG BY: MCKENZIE, ZACH	

NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.

REVISION HISTORY

DWG NO: 00127403

REVISION HISTORY - LEGACY				
REV	DESCRIPTION / REQUESTOR	ECN NO	DATE	REV BY
0.0	ORIGINAL ISSUE	23655	02/01/21	JCS
0.1	ADD STATIONARY JAMB VIEW; UPDATE SILL AND OPERATOR JAMB VIEWS	23655	04/09/21	JTO

3	ADDED VIVID USAGE	27638	03/12/2025	MAF
2	ADDED CONFIGURATION TABLE	28033	1/18/2024	NRF
0.1	ADD STATIONARY JAMB VIEW; UPDATE SILL AND OPERATOR JAMB VIEWS	23655	04/09/21	JTO
REV	DESCRIPTION / REQUESTOR	ECN NO	DATE	REV BY

NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.