


SHEET LEGEND

Sheet: 1 of 1

PRIMARY

**NOTES:**

1. FOR GENERAL SPECIFICATIONS, REFER TO DOC 00003952
2. THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING AND SEALING INSTRUCTIONS, REFER TO INSTALLATION INSTRUCTIONS
3. SHIM APPLICATION:
 - SHIM TO BE PLACED AT EACH HINGE, LOCKING POINT AND THROUGH-JAMB SCREW LOCATION
 - SHIMS TO BE PLACED 4" TO 6" FROM EACH CORNER
 - ADDITIONAL SHIMS TO BE PLACED MAX 15" APART ON-CENTER
4. SCREW APPLICATION:
 - ALL CONFIGURATIONS: EACH PRE-DRILLED JAMB LINER LOCATION, (3) PER JAMB, (2) PER PANEL ALONG HEAD JAMB
 - (2) THROUGH TOP AND BOTTOM HOLE OF EACH HINGE, WHERE APPLICABLE
 - (1) THROUGH CENTER HOLE OF JAMB STRIKE PLATE, WHERE APPLICABLE
 - (1) THROUGH SILL BRACKET AT UNIT CENTERLINE (XX HP UNITS ONLY)
 - THROUGH ACCESSIBLE OUTER HOLE(S) OF HEAD JAMB STRIKE PLATE OR RETAINER PLATE AS INDICATED
5. IF CHEMICALLY TREATED LUMBER IS USED FOR BUCK MATERIAL, FASTENERS INTO BUCK MUST BE A MINIMUM OF 0.90 OZ/FT² ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316
- △ 6. MINIMUM SCREW EMBEDMENT DEPTH: 1-1/4"
- △ 7. MINIMUM EXTERIOR EDGE DISTANCE: 5/8"
- △ 8. MINIMUM INTERIOR EDGE DISTANCE: 1-1/2"
9. GLASS COMPLIES WITH ASTM E1300
- △ 10. NAILING FIN IS OPTIONAL AND NOT REQUIRED FOR STRUCTURAL PERFORMANCE
11. FOR ELEVATIONS, REFER TO DOC 00131455

9	00064718	3/4 THD CROSS RECESSED FLAT No.10 X 2.750 MAS
8	00083201	BRACKET, SILL, INSTALLATION, HP/IZ3
7	00005332	DRIP CAP
6	00005291	NAILING FIN
5	--	ASTM C920 GRADE NS CLASS 25 SEALANT
4	--	SHIM
3	--	FRAMING MATERIAL
2	--	3/4 THD CROSS RECESSED FLAT No. 8-15 X 2.500 A
1	--	2" GALVANIZED ROOFING NAIL
ITEM	DWG NO	DESCRIPTION

PARTS LIST

MARVIN  **RESEARCH & DEVELOPMENT**

COLLECTION: ELEVATE,

 DWG TYPE: INSTALLATION
 DESCRIPTION: INSTALLATION METHODS

SHEET NAME: PRIMARY (1 OF 1)

CHK:	JAJ	SIZE:	B	CLASS:	ASSY	DWG NO:	00131456	REV:	1
APP:	JHS	SCALE:	1 : 4	DATE:	1/16/2024	DWG BY:	ODEGAARD, JON		

1	ADDED DETAIL A, UPDATED NOTES 3 (SHIM APPLICATION) AND 4 (SCREW APPLICATION)	28359	10/4/2024	JEO
0	ORIGINAL ISSUE	28135	1/16/2024	JEO
REV	DESCRIPTION / REQUESTOR	ECN NO	DATE	REV BY

 CATEGORY:
 SWINGING FRENCH DOOR,

 UNIT TYPE:
 ELOFDG3,
NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.

Template Version 15