



NAIL FIN WITH CLIPS INSTALLATION

HEAD JAMB




TYPE	LAMINATED GLASS MAKEUP
TYPE A	2.2mm (.087") ANN + 2.3mm (.090") SGP + 2.2mm (.087") ANN

LAMINATED GLASS:
SEE TABLE ABOVE




STRUCTURAL BRACKET INSTALLATION


HEAD JAMB




JAMB




SILL



SILL



JAMB



NOTES:

- FOR GENERAL SPECIFICATIONS, REFER TO DOC 00003952
- THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING & SEALING INSTRUCTIONS, REFER TO THE INSTALLATION INSTRUCTIONS

- △ 3. SHIMS: PLACE SHIMS WITHIN 4" - 6" OF EACH CORNER AND SPACE ALL OTHERS EVENLY, A MAXIMUM OF 15" APART
4. IF CHEMICALLY TREATED LUMBER IS USED FOR FRAMING MATERIAL, FASTENERS INTO THE FRAMING MUST BE A MINIMUM OF 0.90 OZ/FT^2 ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316
5. #8 X 1-1/4" PAN HEAD OR WAFFLE HEAD SCREWS MAY BE SUBSTITUTED FOR 2" ROOFING NAILS

- △ 6. MINIMUM NAIL EMBEDMENT DEPTH: 1-15/16"
- △ 7. MINIMUM EDGE DISTANCE: 1/2"
- △ 8. MINIMUM SCREW EMBEDMENT DEPTH: 1-7/16"
- △ 9. MINIMUM SCREW EMBEDMENT DEPTH: 1-1/4"
- △ 10. GLASS COMPLIES WITH ASTM E1300

11. FOR INSTALLATION ELEVATIONS AND SPECIFIC SCREW LOCATIONS, REFER TO 00052740

11	NA	APA RATED CONSTRUCTION ADHESIVE
10	NA	ASTM C920 GRADE NS CLASS 25 SEALANT
9	NA	1-1/4" DRYWALL SCREW
8	NA	1-5/8" DRYWALL SCREW
7	00003778	STRUCTURAL BRACKET 6" & 10"
6	00051456	IMPACT FRAME INSTALLATION CLIP
5	00003212	#7 X 5/8" SCREW
4	NA	2" GAL. ROOF NAIL
3	NA	SHIMS
2	NA	FRAMING
1	NA	SHEATHING

ITEM	DWG NO	DESCRIPTION
PARTS LIST		

CATEGORY: DOUBLE HUNG
UNIT TYPE: ELDH IZ3

MARVIN  **RESEARCH & DEVELOPMENT**

COLLECTION: ELEVATE

DWG TYPE: INSTALLATION
DESCRIPTION: INSTALLATION METHOD, ELDH IZ3

CHK: SIZE: B CLASS: MISC DWG NO: 00139306

APP: SCALE: 1 : 3 DATE: 8/16/2023 DWG BY: Jackie Hernandez SHEET: 1 OF 1

NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.