



Supplemental Instructions



Full View Aluminum Doors

 CAUTION	Higher wind pressures and larger doors require additional reinforcement. Premature failure of door system may result from improper application. See chart in lower left corner of drawing sheet one for the approved wind pressures and door sizes.
 WARNING	These supplemental instructions do not contain basic door installation steps and related safety information. Failure to follow basic installation steps and related safety information may result in injury or death. Door installers must follow a primary instruction manual for basic door installation steps and related safety information.

The correct selection of door and framing materials in adherence with local building code directives is the responsibility of the building owner/designer. Use of a reinforced garage door does not constitute automatic compliance with any building code. Local building code officials determine compliance criteria.

A locking system must be installed if the door is not electrically operated.

See drawing for stop molding requirements, when door is not more than 1" wider than opening. When using stop molding, secure molding with minimum 8d nails or 2-1/2" long screws.



Digitally signed by John E Scates
Date: 2026.08.14 22:57:36 -05'00'

John E. Scates, P.E.
PO Box 5175
Frisco, TX 75035
FL PE 51737
TX PE 56308 / F-2203

Professional Engineer's seal
provided only for verification of
windload construction details


For Use With Drawing Number Z0-09-64305

Strut Placement

Section Number	Door Height								
	6'-0" to 8'-0"	8'-3" to 10'-0"	10'-3" to 12'-0"	12'-3" to 14'-0"	14'-3" to 16'-0"	16'-3" to 18'-0"	18'-3" to 20'-0"	20'-3" to 22'-0"	22'-3" to 24'-0"
12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0
11	N/A	N/A	N/A	N/A	N/A	N/A	N/A	0	0
10	N/A	N/A	N/A	N/A	N/A	N/A	0	0	0
9	N/A	N/A	N/A	N/A	N/A	0	0	0	0
8	N/A	N/A	N/A	N/A	0	0	0	0	0
7	N/A	N/A	N/A	0	0	0	0	0	0
6	N/A	N/A	0	0	0	0	0	0	0
5	N/A	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0
1	0	0	0	0	0	0	0	0	0

Push Nut Detail (use on all rollers)


- use 3/8" I. D. on bottom fixture roller stem
- use 7/16" I. D. on end hinge and top fixture roller stems



Track Bracket Spacing


Track bracket spacing shown for doors up to four sections high. Additional door sections may be added for maximum door height depicted on line drawing. Track brackets must be added (per track) for each section and spaced at a distance not greater than the corresponding section height (see line drawing for required quantities).

	Do Not Exceed
E	16"
D	14"
C	24"
B	24"
A	10"





+/- 3" tolerance

For Use With Drawing Number
Z0-09-64305



0 Struts

Glazing Options: max daylight opening 49-1/8" x 19"
 Single Pane (max +20.8 PSF)
 1/8" Annealed DSB
 1/8" Polycarbonate
 1/4" Tempered Glass
 .049" Aluminum Panel
 Double Pane (max +45.6 PSF)
 7/16" Insulated Glass Comprised of two 1/8" Annealed DSB
 7/16" Insulated Glass Comprised of two 1/8" Tempered Glass
 7/16" Insulated Aluminum Panel Comprised of two .049" aluminum panels with 3/8" polystyrene core



Door Height	Section Quantity	Strut Quantity	Trk Brkt Per Side
6'-0" to 8'-0"	4	0	4
8'-3" to 10'-0"	5	0	5
10'-3" to 12'-0"	6	0	6
12'-3" to 14'-0"	7	0	8
14'-3" to 16'-0"	8	0	9
16'-3" to 18'-0"	9	0	10
18'-3" to 20'-0"	10	0	12
20'-3" to 22'-0"	11	0	13
22'-3" to 24'-0"	12	0	14

Track bracket quantities shown are for use with grade 2 or better Southern Yellow Pine. Refer to Jamb Attachment Detail supplemental instructions for usage of alternate jamb materials.

Supporting structural elements shall be designed by a registered professional engineer for wind loads shown on this drawing. If door is not electrically operated, a lock must be installed.

Width	Single Pane Glazing Design Pressure (PSF)	Double Pane Glazing Design Pressure (PSF)	Stile Qty.
18'-02"	+11.6 / -13.0	+11.6 / -13.0	4
16'-02"	+14.7 / -16.4	+14.7 / -16.4	3
14'-02"	+19.1 / -21.4	+19.1 / -21.4	3
12'-02"	+20.8 / -29.0	+25.9 / -29.0	2
10'-02"	+20.8 / -41.5	+37.1 / -41.5	2
9'-06"	+20.8 / -47.6	+42.5 / -47.6	1
9'-02"	+20.8 / -51.1	+45.6 / -51.1	1
8'-02"	+20.8 / -57.4	+45.6 / -57.4	1



Complies with current FBC (See Eval Report)

Complies with IBC/IRC 2018/2021/2024 (Texas)

Tested per ANSI/DASMA 108

Maximum door height: 24'-00"

Glazing and door have not been tested for windborne debris.




Professional Engineer's seal provided only for verification of windload construction details

John E. Scates, P.E.
 PO Box 5175
 Frisco, TX 75035
 FL PE 51737
 TX PE 56308 / F-2203


C.H.I. 333 OVERHEAD DOORS	SCALE	nts
	DATE	10-06-2023
Models Series: Aluminum Full View		
C.H.I. Drawing: Z0-09-64305		
page 4 of 5		

Details on some views may have been omitted for clarity.


Top Fixture
(.059) galvanized steel top fixture
attached with
four 1/4" x 3/4" screws.



Optional Top Fixture
(.109) galvanized steel top fixture
attached with
two 1/4" x 3/4" x 3/4" screws.




The vertical wood jamb fasteners may be counter sunk to provide a flat mounting surface.
See jamb attachment details for more information about attaching jambs to structure.




2" (min) x .0485 (min)
galvanized steel track


Flag Bracket
(.086) galvanized
steel flag bracket
attached to wood
jamb with three
5/16" x 1-5/8"
wood lag screws, to
horizontal track
with two 1/4" x 5/8"
track bolts and nuts
and to vertical track
with two 1/4" x 5/8"
track bolts and nuts.



Track Bracket
(.102) galvanized steel track
bracket attached to wood
jamb with one 5/16" x 1-5/8" wood
lag screw per bracket and
attached to vertical track with
one 1/4" x 5/8" track bolt and
nut or two 1/4" x 11/32" rivets.




End Hinge
galvanized steel
attached with
four 1/4" x 3/4" screws.




2" (max. for .069 thick)
4" (max. for .109 thick)


Intermediate Hinge
(.058) galvanized steel
attached with
four 1/4" x 3/4" screws.






nominal Ø 2" (min.)
10 (min.) ball roller
with nylon or steel tire.



Bottom Bracket
(.102) galvanized steel bottom bracket
attached with
four red 1/4" x 3/4" screws.



Optional Bottom Bracket
(.109) galvanized steel bottom bracket
attached with
four red 1/4" x 3/4" screws.



Professional Engineer's seal provided
only for verification of windload
construction details

John E. Scates, P.E.
PO Box 5175
Frisco, TX 75035
FL PE 51737
TX PE 56308 / F-2203

C.H.I. 333 VERIFIED DRAWING	SCALE	nts
	DATE	10-06-2023
Models Series: Aluminum Full View		
C.H.I. Drawing: Z0-09-64305		
page 5 of 5		