

NOTES:

1. GLAZING OPTION — .090" MINIMUM SSB GLAZING IN MOLDED FRAMES SCREWED TOGETHER WITH A MINIMUM OF (12) #8x3/4" SCREWS INSTALLED IN TOP OR INTERMEDIATE SECTION (WITH OR WITHOUT DECORATIVE INSERTS) MEETS UNIFORM STATIC WIND PRESSURES SHOWN ON THIS DRAWING. GLAZING SHALL HAVE A MAXIMUM HEIGHT OF 14" AND A MAXIMUM LENGTH OF 17". GLAZING IS NOT IMPACT RESISTANT AND DOES NOT MEET THE REQUIREMENTS FOR WIND-BORNE DEBRIS REGIONS.

2. VINYL OR WOOD DOOR STOP NAILED A MAXIMUM OF 6" O.C. MUST OVERLAP TOP AND BOTH ENDS OF PANELS MINIMUM 7/16" TO MEET NEGATIVE PRESSURES.

3. KEY LOCK OR SLIDE LOCKS REQUIRED.

4. SECTIONS SHALL BE CONSTRUCTED WITH .052" MINIMUM VINYL FACER AND .032" MINIMUM VINYL BACKER WITH A POLYURETHANE CORE.

5. SECTIONS SHALL HAVE 1-1/4" x 1-1/2" x 22 GA CONTINUOUS INTERNAL RAILS AT THE TOP AND BOTTOM OF EACH SECTION. THE ENDS OF EACH RAIL IN THE TOP OF EACH SECTION SHALL BE REINFORCED WITH A 15 GA REINFORCING BRACKET.

6. SECTIONS SHALL HAVE 20 GA BACKUP PLATES AT ALL INTERMEDIATE HINGE LOCATIONS.

7. THE DESIGN OF THE SUPPORTING STRUCTURAL ELEMENTS SHALL BE THE RESPONSIBILITY OF THE PROFESSIONAL OF RECORD FOR THE BUILDING OR STRUCTURE AND IN ACCORDANCE WITH CURRENT BUILDING CODES FOR THE LOADS LISTED ON THIS DRAWING.

8. DOOR JAMB SHALL BE MINIMUM 2x6 STRUCTURAL GRADE LUMBER. REFER TO JAMB CONNECTION SUPPLEMENT FOR ATTACHMENT TO SUPPORTING STRUCTURE.

9. CONCRETE FLOOR SHALL BE 3-1/2" THICK AND 2500 PSI MINIMUM.


13 GA HORIZ ANGLE
13 GA FLAG ANGLE
16 GA MIN HORIZ TRACK
5/16x1-5/8" LAG SCREWS (MIN 4 AS SHOWN)
(4) 1/4-20x9/16" TRACK BOLTS & 1/4-20 HEX NUTS
1/4-20x9/16" TRACK BOLT AND 1/4-20 HEX NUT AT EACH JB-US JAMB BRACKET LOCATION
15 GA MIN VERT TRACK

5/16x1-5/8" LAG SCREW AT EACH JAMB BRACKET

15 GA STIFFENED JAMB BRACKETS SEE SCHELDULE FOR QUANTITY, LOCATION, AND TYPE

KEY LOCK OR SLIDE LOCK EACH END (SEE NOTE 3). SLIDE LOCK SHOWN FOR CLARITY.

NOTE: (4) SECTION SOLID DOOR SHOWN. SEE SHEET 2 FOR U-BAR LOCATIONS FOR (5) SECTION DOORS AND SEE NOTE 1 ON THIS SHEET FOR GLAZING OPTION.



REVISIONS


P1 ADDED TEXAS LICENSE NUMBER TO TITLE BLOCK.
10/30/08 GRT
P2 CORRECTED GLAZING NOTE
5/18/09 GRT
P3 UPDATED TITLE BLOCK
GRT 5/5/10
P4 UPDATED TITLE BLOCK
ESC 10/16/17

SUPERIMPOSED DESIGN PRESSURE LOADS ON SUPPORTING STRUCTURE

DOOR WIDTH	DOOR HEIGHT	UNIFORM LOAD EACH JAMB (PLF)	POINT LOAD AT HEADER AND SLAB AT EACH POST LOCATION (LBS)
18'-0"	7'-0"	+352.8/-393.3	+1223.5/-1364.0
	8'-0"	+352.8/-393.3	+1390.4/-1550.0

JAMB BRACKET SCHEDULE

DOOR HEIGHT	NO. OF SECTIONS	NO. OF JAMB BRACKETS (EACH JAMB)	LOCATION OF CENTERLINE OF JAMB BRACKETS MEASURED FROM BOTTOM OF TRACK (ALL DIMENSIONS ± 2")
6'-6"	4	4	2" (JB-US), 21-3/4" (JB-US), 39" (JB-US), 57-1/4" (JB-US)
7'-0"	4	4	2" (JB-US), 21-3/4" (JB-US), 42" (JB-US), 63-1/4" (JB-US)
7'-6"	5	5	2" (JB-US), 18-3/4" (JB-US), 36" (JB-US), 54-1/4" (JB-US), 74-1/2" (JB-US)
8'-0"	5	5	2" (JB-US), 21-3/4" (JB-US), 39" (JB-US), 57-1/2" (JB-US), 75-1/2" (JB-US)



DWAYNE J. KORNISH, PE
4576 COUNTY ROAD 160
MOUNT HOPE, OHIO
FL PE 77945
TX PE 117868

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.


NOTE:

(JB-US) FOLLOWING DIMENSION DENOTES SLOTTED JAMB BRACKET ATTACHED TO TRACK WITH 1/4-20x9/16" TRACK BOLT AND NUT AS SHOWN ABOVE.


Wayne Dalton
GARAGE DOORS™

A DIVISION OF OVERHEAD DOOR CORP
3395 ADDISON DRIVE
PENSACOLA, FLORIDA 32514
(850) 474-9890


STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+39.20/−43.70	MAX WIDTH:	18′−0″		DATE	NAME	
TEST (PSF):	+58.80/−65.55	MAX HEIGHT:	8′−0″	DRAWN	7/27/07	GRT	
IMPACT/CYCLIC RATED (YES/NO): NO		MAX SECTION HEIGHT: 21″		CHECKED	8/1/07	MRB	
MODEL 8700				SHEET 1 OF 2			
WINDLOAD SPECIFICATION OPTION CODE 1042				DRAWING PART NO. 329480		REV. P4	




DETAIL A




DETAIL B



DETAIL C




DETAIL D




DETAIL E

13 GA ROLLER SLIDE ATTACHED TO BRACKET WITH 5/16-18 BOLT & NUT IN CENTER SLOT AND 1/4-20x9/16\"/>




DETAIL F




DETAIL G

INTERMEDIATE HINGE, BACKUP PLATE, AND POST LOCATION



U-BAR LOCATIONS




ATTACH U-BAR WITH (1) 1/4-14x7/8\"/>

NOTE: U-BARS LOCATED ON TOP OF SECTIONS SHALL BE PLACED ON TOP OF BOTTOM HINGE LEAFS AS SHOWN (NOT APPLICABLE TO TOP SECTION)

NOTE: ALUMINUM POST NOT SHOWN FOR CLARITY

REVISIONS	
P1	ADDED TEXAS LICENSE NUMBER TO TITLE BLOCK. 10/30/08 GRT
P2	CORRECTED GLAZING NOTE 5/18/09 GRT
P3	UPDATED TITLE BLOCK GRT 5/5/10
P4	UPDATED TITLE BLOCK ESC 10/16/17



PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

Wayne Dalton
GARAGE DOORS™

A DIVISION OF OVERHEAD DOOR CORP.
3395 ADDISON DRIVE
PENSACOLA, FLORIDA 32514
(850) 474-9890

STATIC PRESSURE RATINGS		APPROVED SIZES		SCALE: N.T.S.		SIZE: A	
DESIGN (PSF):	+39.20/−43.70	MAX WIDTH: 18′−0″			DATE	NAME	
TEST (PSF):	+58.80/−65.55	MAX HEIGHT: 8′−0″		DRAWN	7/27/07	GRT	
IMPACT/CYCLIC RATED (YES/NO): NO		MAX SECTION HEIGHT: 21″		CHECKED	8/1/07	MRB	
MODEL 8700				SHEET 2 OF 2			
WINDLOAD SPECIFICATION OPTION CODE 1042				DRAWING PART NO.		REV.	
				329480		P4	