

GENERAL NOTES:

1. THIS PRODUCT HAS BEEN TESTED, ANALYZED & APPROVED FOR DESIGN PRESSURES NOT TO EXCEED THOSE SHOWN IN THE "ALLOWABLE DESIGN PRESSURE TABLE(S)".
2. OPENINGS, BUCKING & BUCKING FASTENERS MUST BE PROPERLY DESIGNED & INSTALLED TO TRANSFER WIND LOADS TO THE STRUCTURE.
3. ALL HARDWARE & FASTENERS SHALL BE IN ACCORDANCE WITH THESE DRAWINGS & SHALL NOT VARY UNLESS SPECIFICALLY MENTIONED ON THE DRAWINGS. SPECIFIED ANCHOR EMBED TO BASE MATERIAL SHALL BE BEYOND WALL FINISH OR STUCCO.
4. THIS PRODUCT HAS BEEN DESIGNED IN ACCORDANCE WITH AND MEETS THE REQUIREMENTS OF THE FLORIDA BUILDING CODE (FBC) INCLUDING HIGH VELOCITY HURRICANE ZONES (HVHZ) & IS BOTH SMALL & LARGE MISSILE IMPACT RATED.
5. WHEN GLAZED FOR SMALL MISSILE IMPACT, THIS PRODUCT MAY NOT BE INSTALLED AT ELEVATIONS BELOW 30 FT. ABOVE GRADE OR AT ANY CODE DESIGNATED LARGE MISSILE IMPACT LOCATION WITHOUT AN APPROVED SHUTTER.
6. WHEN LARGE MISSILE IMPACT GLAZED, IMPACT SHUTTERS ARE NOT REQUIRED WITH THIS PRODUCT.
7. ALL ANCHORS SECURING PRODUCT FRAMES TO PRESSURE TREATED BUCKS OR WOOD FRAMING SHALL BE CAPABLE OF RESISTING CORROSION CAUSED BY THE PRESSURE TREATING CHEMICALS IN THE WOOD.
8. DETERMINE THE POSITIVE & NEGATIVE DESIGN LOADS TO USE WHEN REFERENCING THESE DOCUMENTS IN ACCORDANCE WITH THE GOVERNING CODE AND GOVERNING WIND VELOCITY. FOR WIND LOAD CALCULATIONS IN ACCORDANCE WITH THE FLORIDA BUILDING CODE, A DIRECTIONALITY FACTOR OF $K_d = 0.85$ MAY BE APPLIED PER THE ASCE-7 STANDARD.
9. MATERIALS, INCLUDING BUT NOT LIMITED TO STEEL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF FLORIDA BUILDING CODE.
10. TO THE BEST OF OUR KNOWLEDGE, THE PRODUCT SHOWN HEREIN IS QUALITY ASSURED BY A FLORIDA STATE APPROVED CERTIFICATION/QA ENTITY & SHALL BE LABELED IN ACCORDANCE WITH THE FBC AND THE FLORIDA DEPARTMENT OF BUSINESS & PROFESSIONAL REGULATION SPECIFICATIONS. THESE DRAWINGS SHOW ALL APPLICABLE ELEVATION, COMBINATION, INSTALLATION & COMPARATIVE ANALYSIS CONDITIONS AS DETERMINED THROUGH TESTING & ENGINEERING RATIONAL ANALYSIS. PRODUCT ASSEMBLY SHALL BE IN ACCORDANCE WITH THESE DRAWINGS, THE MANUFACTURER'S QUALITY ASSURANCE SPECIFICATIONS & TESTING REPORTS.
11. CERTIFICATION OF THIS PRODUCT SHALL BE CONSIDERED VOID IF IT IS INSTALLED WITHOUT A BUILDING PERMIT FROM THE APPLICABLE LOCAL BUILDING DEPARTMENT OR IF IT IS INSTALLED BY ANYONE OTHER THAN A LICENSED CONTRACTOR EXPERIENCED WITH INSTALLATIONS OF THIS TYPE OF PRODUCT.

CORNER CONSTRUCTION:

FRAME: MEMBERS ARE MITER CUT, BUTTED & JOINED VIA TWO(2) SHEAR BLOCKS (PART #'S 11 & 12). EACH SHEAR BLOCK IS FASTENED TO THE FRAME MEMBER WITH TWO(2) 5MM X 20MM SCREWS (2 PER BLOCK; 4 PER CORNER). CORNERS, ACCESS HOLES AND SCREW HEADS ARE SEALED WITH TREMCO 600 SILICONE SEALANT & A $\phi 1/2$ X 2" BACKER ROD BETWEEN THE THERMAL BREAK.
RAIL TO STYLE: MEMBERS ARE MITER CUT, BUTTED & JOINED VIA A SHEAR BLOCK (PART #13). THE SHEAR BLOCK IS SNAP FIT INTO THE STILES & RAILS. CORNERS AND ACCESS HOLES ARE SEALED WITH TREMCO 600 SILICONE SEALANT.


EVALUATION OF THIS PRODUCT IS BASED ON APPLICABLE STANDARDS AND/OR INFORMATION & RESULTS FROM APPLICABLE TEST REPORTS. THE FLORIDA BUILDING CODE VERSION CONSIDERED WITH THIS EVALUATION WAS THAT IN FORCE AT THE TIME OF THE EVALUATION. IN THE EVENT OF CODE VERSION CHANGES/UPDATES OR IN THE EVENT THAT NEW OR ADDITIONAL TESTING IS COMPLETED ON THIS PRODUCT, PRIOR TO STATING CODE COMPLIANCE WITH THE STATE, THE MANUFACTURER SHALL CONFIRM WITH THE EVALUATION ENGINEER OF RECORD THAT EVERYTHING SPECIFIED HERE-IN IS CURRENT WITH ALL CURRENT TESTING, CODES AND APPLICABLE STANDARDS.

FRAME ANCHOR REQUIREMENTS TABLE

FRAME SCREWS

OPENING TYPE (SUBSTRATE)	FRAME TO OPENING FASTENER TYPE	MINIMUM EMBED	MINIMUM EDGE DIST.
MIN. 2X4 WOOD FRAME OR BUCK (MIN. GR. 3 & $G=0.55$)	NO. 12 SMS OR WOOD SCREW	1 1/4"	7/8"
MIN. 16 GA. 50 KSI METAL STUD	NO. 12 GR. 5 SELF TAP/DRILL SCREW	FULL	1/2"
MIN. 1/8" THK A36 STEEL	NO. 12 GR. 5 SELF TAP/DRILL SCREW	FULL	1/2"
MIN. 0.100" THK 6063-T5 ALUM.	NO. 12 GR. 5 SELF TAP/DRILL SCREW	FULL	1/2"
MIN. C-90 CMU	(1) 1/4" CONCRETE SCREW	1 1/4"	2 1/2"
MIN. 3000 PSI CONCRETE	(1) 1/4" CONCRETE SCREW	1 1/2"	2 1/2"

(1) CONCRETE SCREWS SHALL BE ELCO ULTRACONS, ELCO CRETE-FLEX, ITW RAMSET/RED HEAD TAPCONS OR HILTI KWIK-CON II (HARDENED STEEL OR S.S.).



THESE DRAWINGS ARE APPLICABLE ONLY TO THE PRODUCT SPECIFIED. THEY MAY NOT BE USED FOR THE ASSEMBLY AND/OR INSTALLATION OF ANY OTHER PRODUCT NOR MAY THEY BE USED FOR RATIONAL AND/OR LOCAL APPROVAL OF ANY PRODUCT NOT PRODUCED BY THE MANUFACTURER STATED ON THESE DRAWINGS.

DRAWN BY: W.R.M. CHECKED BY: W.W.S.
PLOT: 1=24 DATE: 08/14/10

NO.	REVISION DESCRIPTION	BY	DATE
A1	UPDATE TO CURRENT STANDARDS	W.R.M.	08/29/11
B1	UPDATE TO CURRENT STANDARDS	W.W.S.	12/15/14

DRAWING TITLE: 2000T TERRACE SMALL & LARGE MISSILE IMPACT IN-SWING DOOR

MANUFACTURER:
KAWNEER COMPANY, INC.
555 GUTHRIE COURT
NORCROSS, GA 30092
770-449-5555

CONSULTANTS:
W. W. SCHAEFER ENGINEERING
& CONSULTING, P.A. (CA 6809)
7480 150TH COURT NORTH
PALM BEACH GARDENS, FL 33418
PHONE: 561-744-3424


CERTIFICATION
JAN 06 2015
W. W. SCHAEFER, P.E.
P.E. NO. 44135






DRAWING NO. 1679 REV. B
SHEET NO. 1 OF 4



ALLOWABLE DESIGN PRESSURE

GLAZING DETAIL	GLASS OPTION	ALLOWABLE PRESSURE (+/- PSF)
LARGE MISSILE IMPACT (L.M.I.) DOORS		
1	1	90
1	2	90
1	3	90
1	4	70
1	5	70
2	6	70
SMALL MISSILE IMPACT (S.M.I.) DOORS		
3	7	90
3	8	90

SEE GLAZING DETAILS ON SHEET 3 FOR GLASS & GLAZING OPTIONS







GLAZING DETAIL 1
(L.M.I. GLASS OPTIONS 1-5)


GLASS OPTION 1: 1" LAMINATED I.G. (3/16" H.S./0.075" EASTMAN CHEM. CO. SAFLEX CP/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)

GLASS OPTION 2: 1" LAMINATED I.G. (3/16" H.S./0.090" DUPONT SG/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)

GLASS OPTION 3: 1" LAMINATED I.G. (3/16" H.S./0.100" EASTMAN CHEM. CO. SAFLEX HP/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)

GLASS OPTION 4: 1" LAMINATED I.G. (3/16" H.S./0.090" DUPONT BUTACITE PVB/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)


GLASS OPTION 5: 1" LAMINATED I.G. (3/16" H.S./0.090" EASTMAN CHEM. CO. SAFLEX/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)



GLAZING DETAIL 2
(L.M.I. GLASS OPTION 6)


GLASS OPTION 6: 1" LAMINATED I.G. (3/16" H.S./0.090" DUPONT SG/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)

L.M.I. = LARGE MISSILE IMPACT
S.M.I. = SMALL MISSILE IMPACT



OPTIONAL DIRECT MOUNT DETAIL
TO SUBSTRATE WITH SPACER


(HEAD SECTION SHOWN; SILL & SIDES ARE INSTALLED THE SAME)
(FOR DETAIL NOT SHOWN, SEE OTHER SECTIONS)



GLAZING DETAIL 3
(S.M.I. GLASS OPTIONS 7 & 8)

GLASS OPTION 7: 1" LAMINATED I.G. (3/16" H.S./0.060" DUPONT BUTACITE PVB/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)

GLASS OPTION 8: 1" LAMINATED I.G. (3/16" H.S./0.060" EASTMAN CHEM. CO. SAFLEX/3/16" H.S. INTERIOR; 3/8" SPACER; 3/16" TEMPERED EXTERIOR)



DRAWN BY: W.R.M.	CHECKED BY: W.W.S.
PLOT: 1-2	DATE: 06/14/10
DATE	
BY	
REVISION DESCRIPTION	
NO.	
DRAWING TITLE 2000T TERRACE SMALL & LARGE MISSILE IMPACT IN-SWING DOOR	MANUFACTURER KANNEER COMPANY, INC. 555 GUTHRIE COURT NORCROSS, GA 30092 770-449-5555
CONSULTANTS W. W. SCHAEFER ENGINEERING & CONSULTING, P.A. (CA 6809) 7480 150TH COURT NORTH PALM BEACH GARDENS, FL 33418 PHONE: 561-744-3424	
CERTIFICATION JAN 06 2013 WARREN W. SCHAEFER, P.E. NO. 44135	
DRAWING NO. 1679	REV. B
SHEET NO. 3	OF 4

