




# THROUGH FRAME INSTALLATION



TYPICAL ELEVATION WITH FASTENER SPACING



FRAME SECTION (TYP)  
VERTICAL SECTION



FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

## Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use #10 PH or greater fastener through the head & side jambs with sufficient length to penetrate a minimum of 1 1/2" into the wood framing. For 2x wood frame substrate (min. S.G. = 0.42).
3. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
4. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

## General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

## DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300


This item has been digitally signed and sealed by Michael D. Stremmel, P.E. on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

|                            |                                                              |                                                                                                          |        |               |
|----------------------------|--------------------------------------------------------------|----------------------------------------------------------------------------------------------------------|--------|---------------|
|                            | DATE:<br>01/04/2024                                          | <div>JELD-WEN</div> <div>3737 LAKEPORT BLVD.<br/>KLAMATH FALLS OR, 97601<br/>PHONE: (800) 535-3936</div> |        |               |
| DRAWN BY:<br>M.HAM         | SCALE:<br>NTS                                                |                                                                                                          |        |               |
| CHECKED BY:<br>D.VEZO      | TITLE:<br><br>Energy Saver Steel Wood Edge Inswing Opaque XO |                                                                                                          |        |               |
| APPROVED BY:<br>D.VEZO     |                                                              |                                                                                                          |        |               |
| RECORD No.:<br>D1000364    |                                                              |                                                                                                          |        |               |
| REPORT No.:<br>SJW2009-200 |                                                              | CAD DWG. No.:<br>—                                                                                       | REV: C | SHEET 1 of 10 |


# MASONRY STRAP INSTALLATION



**TYPICAL ELEVATION WITH FASTENER SPACING**



**FRAME SECTION (TYP)  
VERTICAL SECTION**



**FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS**

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

## Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use 2 - #8 PFH or larger fasteners through masonry strap with sufficient length to penetrate a minimum of 1 1/2" into the buck. For 2x wood frame substrate (min. S.G. = 0.42).
3. Use 2 - #8 PFH or larger fasteners through masonry strap into jamb without penetrating through the jamb into product causing visibility or collateral damage to product.
4. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
5. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

## General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.
4. Masonry strap specifications: 20 Ga. galvanized steel, .036" min. thickness x 1.5" min. width.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

## DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




2024.03.21 12:14:07 -0400

**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300


This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

|                            |                                                              |                                                                                                                                                               |        |               |
|----------------------------|--------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|---------------|
|                            | DATE:<br>01/04/2024                                          |  3737 LAKEPORT BLVD.<br>KLAMATH FALLS OR, 97601<br>PHONE: (800) 535-3936 |        |               |
| DRAWN BY:<br>M.HAM         | SCALE:<br>NTS                                                |                                                                                                                                                               |        |               |
| CHECKED BY:<br>D.VEZO      | TITLE:<br><br>Energy Saver Steel Wood Edge Inswing Opaque XO |                                                                                                                                                               |        |               |
| APPROVED BY:<br>D.VEZO     |                                                              |                                                                                                                                                               |        |               |
| RECORD No.:<br>D1000364    |                                                              |                                                                                                                                                               |        |               |
| REPORT No.:<br>SJW2009-200 |                                                              | CAD DWG. No.:<br>—                                                                                                                                            | REV: C | SHEET 2 of 10 |


# CONCRETE/MASONRY INSTALLATION



TYPICAL ELEVATION WITH FASTENER SPACING



FRAME SECTION (TYP)  
VERTICAL SECTION



FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

## Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use 3/16" tapcon or equivalent fasteners through frame with sufficient length to penetrate a minimum of 1 1/4" into concrete or masonry at each location with a 2 1/2" min. from edge distance. For concrete (min. fc = 3000 psi) or masonry substrate (CMU shall adhere to ASTM C90).
3. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
4. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

## General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

## DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




2024.03.21 12:14:07 -0400


**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300

This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.


|                            |                                                              |                                                                                                                                                               |        |               |
|----------------------------|--------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|---------------|
|                            | DATE:<br>01/04/2024                                          |  3737 LAKEPORT BLVD.<br>KLAMATH FALLS OR, 97601<br>PHONE: (800) 535-3936 |        |               |
| DRAWN BY:<br>M.HAM         | SCALE:<br>NTS                                                |                                                                                                                                                               |        |               |
| CHECKED BY:<br>D.VEZO      | TITLE:<br><br>Energy Saver Steel Wood Edge Inswing Opaque XO |                                                                                                                                                               |        |               |
| APPROVED BY:<br>D.VEZO     |                                                              |                                                                                                                                                               |        |               |
| RECORD No.:<br>D1000364    |                                                              |                                                                                                                                                               |        |               |
| REPORT No.:<br>SJW2009-200 |                                                              | CAD DWG. No.:<br>—                                                                                                                                            | REV: C | SHEET 3 of 10 |



**TYPICAL ELEVATION WITH FASTENER SPACING**



**FRAME SECTION (TYP)  
VERTICAL SECTION**



**FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS**

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

#### Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use (1) - 1/4" Tapcon or equivalent fasteners through strap with sufficient length to penetrate a minimum of 1 1/4" into concrete or masonry at each location with a 2 1/2" min. from edge distance. Use (2) - #8 PFH fasteners through masonry strap into frame. For concrete (min.  $f_c = 3000$  psi) or masonry substrate (CMU shall adhere to ASTM C90).
3. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
4. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

#### General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.
4. Masonry strap specifications: 20 Ga. galvanized steel, .036" min. thickness x 1.5" min. width.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

#### DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




2024.03.21 12:14:07 -0400

**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300


This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

|                            |                                                              |                                                                                                          |        |               |
|----------------------------|--------------------------------------------------------------|----------------------------------------------------------------------------------------------------------|--------|---------------|
|                            | DATE:<br>01/04/2024                                          | <div>JELD-WEN</div> <div>3737 LAKEPORT BLVD.<br/>KLAMATH FALLS OR, 97601<br/>PHONE: (800) 535-3936</div> |        |               |
| DRAWN BY:<br>M.HAM         | SCALE:<br>NTS                                                |                                                                                                          |        |               |
| CHECKED BY:<br>D.VEZO      | TITLE:<br><br>Energy Saver Steel Wood Edge Inswing Opaque XO |                                                                                                          |        |               |
| APPROVED BY:<br>D.VEZO     |                                                              |                                                                                                          |        |               |
| RECORD No.:<br>D1000364    |                                                              |                                                                                                          |        |               |
| REPORT No.:<br>SJW2009-200 |                                                              | CAD DWG. No.:<br>—                                                                                       | REV: C | SHEET 4 of 10 |


# MASONRY STRAP INSTALLATION



TYPICAL ELEVATION WITH FASTENER SPACING



FRAME SECTION (TYP)  
VERTICAL SECTION



FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

## Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use min. 2 - #8 PFH or larger fasteners through masonry strap with sufficient length to penetrate a minimum of 1 1/2" into the buck. Bend straps around both sides of the buck. For 2x wood frame substrate (min. S.G. = 0.42).
3. Use min. 2 - #8 PFH or larger fasteners through masonry strap into jamb without penetrating through the jamb into product causing visibility or collateral damage to product.
4. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
5. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

## General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.
4. Masonry strap specifications: 20 Ga. galvanized steel, .036" min. thickness x 1.5" min. width.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

## DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




2024.03.21 12:14:07 -0400

**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300



This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

|                            |                                                          |                                                                                         |                      |
|----------------------------|----------------------------------------------------------|-----------------------------------------------------------------------------------------|----------------------|
| DRAWN BY:<br>M.HAM         | DATE:<br>01/04/2024                                      | <b>JELD-WEN</b> 3737 LAKEPORT BLVD.<br>KLAMATH FALLS OR, 97601<br>PHONE: (800) 535-3936 |                      |
| CHECKED BY:<br>D.Vezo      | SCALE:<br>NTS                                            |                                                                                         |                      |
| APPROVED BY:<br>D.Vezo     | TITLE:<br>Energy Saver Steel Wood Edge Inswing Opaque XO |                                                                                         |                      |
| REPORT No.:<br>SJW2009-200 | RECORD No.:<br>D1000364                                  | CAD DWG. No.:<br>—                                                                      | REV: C SHEET 5 of 10 |

# THROUGH FRAME INSTALLATION



TYPICAL ELEVATION WITH FASTENER SPACING



| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

## Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use #10 PH or greater fastener through the head & side jambs with sufficient length to penetrate a minimum of 1 1/2" into the wood framing. For 2x wood frame substrate (min. S.G. = 0.42).
3. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
4. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.


## General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

## DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300


This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

|                                                                                                                                |                     |                                                                                         |                  |
|--------------------------------------------------------------------------------------------------------------------------------|---------------------|-----------------------------------------------------------------------------------------|------------------|
| DRAWN BY:<br>M.HAM<br>CHECKED BY:<br>D.Vezo<br>APPROVED BY:<br>D.Vezo<br>RECORD No.:<br>D1000364<br>REPORT No.:<br>SJW2009-200 | DATE:<br>01/04/2024 | <b>JELD-WEN</b> 3737 LAKEPORT BLVD.<br>KLAMATH FALLS OR, 97601<br>PHONE: (800) 535-3936 |                  |
|                                                                                                                                | SCALE:<br>NTS       |                                                                                         |                  |
|                                                                                                                                | TITLE:              | Energy Saver Steel Wood Edge Outswing Opaque XO                                         |                  |
|                                                                                                                                | CAD DWG. No.:<br>—  | REV:<br>C                                                                               | SHEET<br>6 of 10 |


MASONRY STRAP  
INSTALLATION




TYPICAL ELEVATION WITH FASTENER SPACING



FRAME SECTION (TYP)  
VERTICAL SECTION



FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS



| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

Installation Notes:


1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use 2 - #8 PFH or larger fasteners through masonry strap with sufficient length to penetrate a minimum of 1 1/2" into the buck. For 2x wood frame substrate (min. S.G. = 0.42).
3. Use 2 - #8 PFH or larger fasteners through masonry strap into jamb without penetrating through the jamb into product causing visibility or collateral damage to product.
4. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
5. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.
4. Masonry strap specifications: 20 Ga. galvanized steel, .036" min. thickness x 1.5" min. width.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

**DISCLAIMER:**  
This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.


**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300

|                            |                                                                                         |                      |
|----------------------------|-----------------------------------------------------------------------------------------|----------------------|
| DATE:<br>01/04/2024        | <b>JELD-WEN</b> 3737 LAKEPORT BLVD.<br>KLAMATH FALLS OR, 97601<br>PHONE: (800) 535-3936 |                      |
| DRAWN BY:<br>M.HAM         |                                                                                         |                      |
| CHECKED BY:<br>D.Vezo      | TITLE:<br>Energy Saver Steel Wood Edge Outswing Opaque XO                               |                      |
| APPROVED BY:<br>D.Vezo     |                                                                                         |                      |
| RECORD No.:<br>D1000364    |                                                                                         |                      |
| REPORT No.:<br>SJW2009-200 | CAD DWG. No.:<br>—                                                                      | REV: C SHEET 7 of 10 |


CONCRETE/MASONRY  
INSTALLATION



TYPICAL ELEVATION WITH FASTENER SPACING



FRAME SECTION (TYP)  
VERTICAL SECTION



FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use 3/16" tapcon or equivalent fasteners through frame with sufficient length to penetrate a minimum of 1 1/4" into concrete or masonry at each location with a 2 1/2" min. from edge distance. For concrete (min. fc = 3000 psi) or masonry substrate (CMU shall adhere to ASTM C90).
3. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
4. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

**DISCLAIMER:**  
This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

*Michael D. Stremmel*  
2024.03.21 12:14:07 -0400


**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300

|                            |                                                                                         |
|----------------------------|-----------------------------------------------------------------------------------------|
| DATE:<br>01/04/2024        | <b>JELD-WEN</b> 3737 LAKEPORT BLVD.<br>KLAMATH FALLS OR, 97601<br>PHONE: (800) 535-3936 |
| DRAWN BY:<br>M.HAM         |                                                                                         |
| CHECKED BY:<br>D.Vezo      | TITLE:<br>Energy Saver Steel Wood Edge Outswing Opaque XO                               |
| APPROVED BY:<br>D.Vezo     |                                                                                         |
| RECORD No.:<br>D1000364    | CAD DWG. No.:<br>—                                                                      |
| REPORT No.:<br>SJW2009-200 |                                                                                         |
| REV:<br>C                  | SHEET<br>8 of 10                                                                        |


# CONCRETE/MASONRY INSTALLATION



**TYPICAL ELEVATION WITH FASTENER SPACING**



**FRAME SECTION (TYP)  
VERTICAL SECTION**



**FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS**

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

## Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use (1) - 1/4" Tapcon or equivalent fasteners through strap with sufficient length to penetrate a minimum of 1 1/4" into concrete or masonry at each location with a 2 1/2" min. from edge distance. Use (2) - #8 PFH fasteners through masonry strap into frame. For concrete (min.  $f_c = 3000$  psi) or masonry substrate (CMU shall adhere to ASTM C90).
3. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
4. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

## General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.
4. Masonry strap specifications: 20 Ga. galvanized steel, .036" min. thickness x 1.5" min. width.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

## DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.




2024.03.21 12:14:07 -0400

**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300


This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

|                            |                                                           |                                                                                         |  |
|----------------------------|-----------------------------------------------------------|-----------------------------------------------------------------------------------------|--|
| DRAWN BY:<br>M.HAM         | DATE:<br>01/04/2024                                       | <b>JELD-WEN</b> 3737 LAKEPORT BLVD.<br>KLAMATH FALLS OR, 97601<br>PHONE: (800) 535-3936 |  |
| CHECKED BY:<br>D.Vezo      | SCALE:<br>NTS                                             |                                                                                         |  |
| APPROVED BY:<br>D.Vezo     | TITLE:<br>Energy Saver Steel Wood Edge Outswing Opaque XO | RECORD No.:<br><b>D1000364</b>                                                          |  |
| REPORT No.:<br>SJW2009-200 | CAD DWG. No.:<br>—                                        |                                                                                         |  |
| REV:<br>C                  | SHEET<br>9 of 10                                          |                                                                                         |  |


# MASONRY STRAP INSTALLATION



**TYPICAL ELEVATION WITH FASTENER SPACING**



**FRAME SECTION (TYP)  
VERTICAL SECTION**



**FRAME JAMB SECTION (TYP)  
HORIZONTAL SECTIONS**

| MAXIMUM FRAME | DP      | IMPACT |
|---------------|---------|--------|
| 51 x 82       | +50/-50 | NO     |

## Installation Notes:

1. Seal flange/frame to substrate. Sill shall be set on a continuous serpentine bead of structural grade silicone caulk when no fastener is used to anchor the sill (typical).
2. Use min. 2 - #8 PFH or larger fasteners through masonry strap with sufficient length to penetrate a minimum of 1 1/2" into the buck. Bend straps around both sides of the buck. For 2x wood frame substrate (min. S.G. = 0.42).
3. Use min. 2 - #8 PFH or larger fasteners through masonry strap into jamb without penetrating through the jamb into product causing visibility or collateral damage to product.
4. Install corrosion resistant (2)- 1/4"x 3" Tapcon screws through each strike plate into rough opening.
5. Host structure (wood buck, masonry, steel) to be designed and anchored to properly transfer all loads to the structure. The host structure is the responsibility of the architect or engineer of record for the project of installation.

## General Notes:

1. The product shown herein is designed, tested and manufactured to comply with the wind load criteria of the adopted International Building Code (IBC), the International Residential Code (IRC), the current Florida Building Code (FBC) and the industry requirement for the stated conditions.
2. All glazing shall conform to ASTM E1300.
3. Use structural or composite shims where required.
4. Masonry strap specifications: 20 Ga. galvanized steel, .036" min. thickness x 1.5" min. width.

This schedule addresses only the fasteners required to anchor the unit to achieve the rated design pressure and impact performance (where applicable) up to the size limitations noted. It is not intended as a guide to the installation process and does not address the sealing consideration that may arise in different wall conditions. For the complete installation procedure, see the instructions packaged with the unit or go to [www.jeld-wen.com](http://www.jeld-wen.com).

## DISCLAIMER:

This drawing and its contents are confidential and are not to be reproduced or copied in whole or in part or used or disclosed to others except as authorized by JELD-WEN Inc.



2024.03.21 12:14:07 -0400

**MICHAEL D. STREMMEL, P.E.**  
Florida P.E. No. 65868, REG. No. 37122  
1410 Eden Road  
York, PA. 17406  
(717) 916-6300

This item has been digitally signed and sealed by Michael D. Stremmel, PE on the date adjacent to the seal. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

|                            |                                                               |                                                                                                          |           |                   |  |
|----------------------------|---------------------------------------------------------------|----------------------------------------------------------------------------------------------------------|-----------|-------------------|--|
|                            | DATE:<br>01/04/2024                                           | <div>JELD-WEN</div> <div>3737 LAKEPORT BLVD.<br/>KLAMATH FALLS OR, 97601<br/>PHONE: (800) 535-3936</div> |           |                   |  |
| DRAWN BY:<br>M.HAM         | SCALE:<br>NTS                                                 |                                                                                                          |           |                   |  |
| CHECKED BY:<br>D.Vezo      | TITLE:<br><br>Energy Saver Steel Wood Edge Outswing Opaque XO |                                                                                                          |           |                   |  |
| APPROVED BY:<br>D.Vezo     |                                                               |                                                                                                          |           |                   |  |
| RECORD No.:<br>D1000364    |                                                               |                                                                                                          |           |                   |  |
| REPORT No.:<br>SJW2009-200 | CAD DWG. No.:<br>—                                            |                                                                                                          | REV:<br>C | SHEET<br>10 of 10 |  |