




NAILING FIN INSTALLATION

- APPLY MULL CLIP TO HEAD JAMB SPACED PER ELEVATION
- APPLY TWO 5/16" BEADS OF APA RATED CONSTRUCTION ADHESIVE
- ATTACH MULL CLIP TO FRAME WITH EIGHT #7 X .625 WOOD SCREWS
- ATTACH MULL CLIP TO FRAMING WITH 1.25" DRYWALL SCREWS
- SECURE NAILING FIN WITH 2" GALVANIZED ROOFING NAILS, MINIMUM OF TWO PER SIDE SPACED A MAX OF 4" FROM CORNERS AND 8" ON CENTER
- NAIL SPACING SHALL BE 4" OFF EACH END AND 7" ON CENTER
- SCREW 5 DRYWALL SCREWS THROUGH EACH MULL CLIP INTO THE ROUGH OPENING


SHIM SPECIFICATIONS

- A SHIM MUST BE PLACED 4" TO 6" FROM EACH CORNER
- ALL OTHER SHIMS MUST BE SPACED A MAX OF 15" APART



NOTES:

1. FOR GENERAL SPECIFICATIONS, REFER TO DOC 00003952
2. THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING & SEALING INSTRUCTIONS, REFER TO THE INSTALLATION INSTRUCTIONS
3. IF CHEMICALLY TREATED LUMBER IS USED FOR FRAMING MATERIAL, FASTENERS INTO THE FRAMING MUST BE A MINIMUM OF 0.90 OZ/FT^2 ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316
4. #8 X 1 1/4" PAN HEAD OR WAFFLE HEAD SCREWS MAY BE SUBSTITUTED FOR 2" ROOFING NAILS
5. ITDH + ITDH/ITDH + ITDH CONFIGURATION SHOWN
6. CONSTRUCTION ADHESIVE IS APPLIED ONLY AT BRACKET LOCATIONS
7. MINIMUM NAIL EMBEDMENT DEPTH: 1 15/16"
8. MINIMUM SCREW EMBEDMENT DEPTH: 1 3/16"
9. MINIMUM EDGE DISTANCE: 1/2"
10. APPROVED PRODUCTS: FL 14133



10	NA	NS CLASS 25 SEALANT ASTM C920
9	NA	CONSTRUCTION ADHESIVE
8	NA	SHEATHING
7	NA	FRAMING
6	NA	SHIMS
5	00046846	#8 X 1.250 PH, BH, COARSE PB 2/3 THRD SCREW
4	NA	2" GALVANIZED ROOFING NAIL
3	00104030	MULL CLIP, JAMB
2	00003212	#7-19 X .625" TYPE AB-17, FULL THREAD
1	00104023	MULL CLIP, SILL
ITEM	DWG NO	DESCRIPTION

PARTS LIST

MARVIN Windows and Doors		RESEARCH & DEVELOPMENT WARROAD, MN, USA, (218) 386-4021	
PRODUCT		INTEGRITY WOOD ULTREX	
CATEGORY:			
UNIT TYPE:		ITDH, ITDHP, IDG, IRTMDH	
DWG TYPE:		INSTALLATION	
DESCRIPTION:		ELEVATION/METHOD, NAIL FIN, CERT-MULL, PUR	
CHK:	CAM	SIZE:	CLASS:
10/18/17		B	ASSY
APP:		DATE:	DWG NO:
10/27/17	JJJ	02/10/17	00104697
DWG BY:		SHEET:	
MURPHY, CASEY		1 OF 1	

NOTICE - CONFIDENTIAL INFORMATION

The information in this document is privileged and strictly confidential. The information contained herein shall be used only by Marvin Windows and Doors employees and by those agents or suppliers granted official written permission. If the reader of this document is not the intended recipient, or the employee or agent of the intended recipient, please delete this document from all data storage devices, and destroy all hard copies. Any unauthorized dissemination, distribution, copying or other use of the information contained in this document is strictly prohibited.