



ARC. Structural Testing

Test sample complies with these details.
 Deviations are noted.


Report 01-46287.61
 Date 10-31-02 Tech. S.B.K.



COILSIDE ELEVATION




VERTICAL DETAIL



NOTES:

1. UNIFORM STATIC AIR PRESSURE TEST PERFORMED PER TAS 202
2. LARGE MISSILE IMPACT TEST PERFORMED ON 3 SAMPLES PER TAS 201 TO QUALIFY INTERIOR & EXTERIOR MOUNT
3. CYCLIC PRESSURE TEST PERFORMED ON 3 SAMPLES PER TAS 203
4. TENSILE TEST PERFORMED ON CURTAIN PER ASTM E 8
5. TESTED BY ARCHITECTURAL TESTING, INC.
6. CURTAIN IS .028 MIN STEEL PER ASTM A 653, GR.40
7. GUIDE ANGLES ARE STRUCTURAL STEEL PER ASTM A 36
8. HOOD IS 24GA GALVANIZED STEEL

TEST	DATE	TEST REPORT NUMBER	RESULTS
UNIFORM STATIC AIR PRESSURE	.	.	.
LARGE MISSILE IMPACT	.	.	.
CYCLIC PRESSURE	.	.	.
TENSILE	.	.	.



GUIDE DETAIL

PART NUMBER	WEIGHT (LB.)	TITLE	DRAWN BY	CHECKED BY	APPROV. BY	TOLERANCES (UNLESS OTHERWISE SPECIFIED)	 Wayne Dalton Rolling Door Division 9432 Lincoln Way E. Dalton, Ohio 44418
REFERENCE		WINDLOAD TEST, 822. 16' x 8', #14 SLAT, HVHZ, ±47 PSF DESIGN (±71 PSF TEST)	M. DAUS 10/15/2003			LINEAR .X ± .060 LINEAR .XX ± .030 LINEAR .XXX ± .010 ANGULAR ± .50° DIMENSIONS IN INCHES	
		MATERIAL	SCALE - WHEN THIS BOX IS .50" HIGH	ORIGINAL RELEASE			
		AS SHOWN	NONE				

THIS DRAWING IS THE PROPERTY OF WAYNE DALTON AND IS LOANED WITH THE EXPRESSED AGREEMENT THAT THE DRAWINGS AND INFORMATION THEREIN CONTAINED ARE THE PROPERTY OF WAYNE DALTON AND WILL NOT BE REPRODUCED, COPIED, OR OTHERWISE DISPOSED OF DIRECTLY OR INDIRECTLY, AND WILL NOT BE USED IN WHOLE OR IN PART TO ASSIST IN MAKING OR TO TENDER ANY INFORMATION FOR THE MAKING OF DRAWINGS, PRINTS, OR OTHER REPRODUCTIONS THEREOF, OR FOR THE MAKING OF APPARATUS OR PARTS THEREOF, EXCEPT UPON WRITTEN PERMISSION OF WAYNE DALTON FIRST OBTAINED AND SPECIFIC AS TO EACH CASE. THE ACCEPTANCE OF THIS DRAWING WILL BE CONSIDERED AS AN ACCEPTANCE OF THE FOREGOING AGREEMENT.

REV.	REV'D. BY	APPROV. BY	RELEASE	DESCRIPTION

REVISIONS

SIZE	DRAWING NO.	REVISION
B	035-0005	