





NOTES:

1. DESIGN PRESSURE = ± 47 PSF, TESTED IN ACCORDANCE WITH TAS 201, TAS 202, AND TAS 203 BY ARCHITECTURAL TESTING, INC. (YORK, PA)
2. ALL WELDING TO CONFORM TO AMERICAN WELDING SOCIETY'S LATEST EDITION AND FLORIDA BUILDING CODE. USE A.W.S. A5.1 OR A5.5 E60XX ELECTRODES.
3. THE CONTRACTOR SHALL ENSURE THAT THE WALL CAN SUPPORT THE JAMB FORCES INDICATED ON THIS DRAWING.
4. WINDLOCKS ON BOTH ENDS OF ALL SLATS (CONTINUOUS).
5. HOODS ARE 24GA GALVANIZED STEEL, STAINLESS STEEL, OR ALUMINUM.
6. ALL GALVANIZING PER ASTM A 653. SHOP COAT OF RUST INHIBITIVE PRIMER ON NONGALVANIZED STEEL SURFACES.
7. DOOR MAY BE LIFT UP, CRANK, HOIST, OR ELECTRIC OPERATION.
8. CURTAIN IS .028 (22 GA) MIN STEEL PER ASTM A 653, GR.40, G90 GALVANIZED.
9. GUIDE AND BOTTOM BAR ANGLES ARE STRUCTURAL STEEL PER ASTM A 36.
10. TESTING PERFORMED ON A 16' WIDE X 10' HIGH DOOR (SHOWN). APPROVAL APPLIES TO DOORS UP TO 16' WIDE X UP TO 30' HIGH WITH COMPONENTS OF EQUAL OR GREATER STRENGTH AND SIZE.
11. OPERATING MECHANISM NOT PART OF THIS APPROVAL MUST BE CERTIFIED BY AN INDEPENDANT THIRD PARTY.
12. THIS DOOR IS CAPABLE OF INTERIOR OR EXTERIOR MOUNTING


PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **18-0815.07**
Expiration Date **01/11/2022**
By *[Signature]*
Miami-Dade Product Control



Approved: **MARK A. SAWICKI, P.E. FL # 72613**
2501 S. STATE HWY 121 SUITE 200
LEWISVILLE, TX 75067


Date: _____

C	DG 5/11/18	RO 5/11/18	ER 503991	UPDATE "C" DIMENSION PER ER	PART NUMBER	WEIGHT (LB.)	TITLE	DRAWN BY	CHECKED BY	APPVD. BY	TOLERANCES (UNLESS OTHERWISE SPECIFIED)	 Wayne Dalton Rolling Door Division 14512 Lincoln Way E. Dalton, Ohio 44618		
B	TJS 11/16/16	TB 11/16/16	ER 503497	UPDATE PRINT TO REFLECT LATEST TEST REPORT F7666.01-109-18	REFERENCE	PAGE 1 OF 2	DADE COUNTY TEST DOORS AND APPROVED MODIFICATIONS, SERIES 800 SERVICE DOOR, HVHZ, ±47 PSF DESIGN UP TO 16' WIDE x UP TO 30' HIGH	10/24/2006		10/26/2006	LINEAR .X ± .060 LINEAR .XX ± .030 LINEAR .XXX ± .010 ANGULAR ± .50"			
1	MED 12/18/06	DLM 12/18/06	PCR R-00424	REV TITLE BLOCK, REV NOTES, REV SLAT DETAIL, REV WINDLOCK DETAIL			MATERIAL	AS SHOWN	SCALE - WHEN THIS BOX IS .50" HIGH	ORIGINAL RELEASE	PCR R-00424		DIMENSIONS IN INCHES	
									NONE					
REV.	REVD. BY	APPVD. BY	RELEASE	DESCRIPTION								SIZE	DRAWING NO.	REVISION
REVISIONS												B	035-0032	BC




(Z) GUIDE MOUNTING DETAIL

GUIDES BOLTED TO CONCRETE JAMB




(E) GUIDE MOUNTING DETAIL

GUIDES BOLTED TO STEEL JAMB



(E) GUIDE MOUNTING DETAIL

GUIDES WELDED TO STEEL JAMB AT SLOT AND TOE




(E) GUIDE MOUNTING DETAIL

GUIDES WELDED TO STEEL JAMB AT SLOT AND HEEL

GUIDE TYPE	FORCE (lbs/ft)	
	POS WINDLOAD	NEG WINDLOAD
Z-GUIDE	Rx = 1319	Rx = 1319
	Ry = 1189	Ry = 1995
	Px = 1319	Px = 1319
	Py+ = 376	Py- = 376
E-GUIDE	Rx = 1319	Rx = 1319
	Ry = 3262	Ry = 2817
	Px = 1319	Px = 1319
	Py+ = 376	Py- = 376

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. **18-0815.07**
Expiration Date **01/11/2022**
By *[Signature]*
Miami-Dade Product Control



Approved: MARK A. SAWICKI, P.E. FL # 72613
2501 S. STATE HWY 121 SUITE 200
LEWISVILLE, TX 75067

Date: _____

C	DG 5/11/18	RO 5/11/18	ER 503991	UPDATE "C" DIMENSION PER ER	PART NUMBER	WEIGHT (LB.)	TITLE	DRAWN BY	CHECKED BY	APPVD. BY	TOLERANCES (UNLESS OTHERWISE SPECIFIED)	 Wayne Dalton Rolling Door Division 14512 Lincoln Way E. Dalton, Ohio 44618		
B	TJS 11/16/16	TB 11/16/16	ER 503497	UPDATE PRINT TO REFLECT LATEST TEST REPORT F7666.01-109-18	REFERENCE PAGE 2 OF 2		DADE COUNTY TEST DOORS AND APPROVED MODIFICATIONS, SERIES 800 SERVICE DOOR, HVHZ, ±47 PSF DESIGN UP TO 16' WIDE x UP TO 30' HIGH	M. DAUS 10/24/2006		DLM 10/26/2006	LINEAR .X ± .060 LINEAR .XX ± .030 LINEAR .XXX ± .010 ANGULAR ± .50"			
1	MED 12/18/06	DLM 12/18/06	PCR R-00424	REV TITLE BLOCK, 7.5 CONCRETE SPACING WAS 8.75, REV GUIDE DETAILS			MATERIAL	AS SHOWN	SCALE - WHEN THIS BOX IS .50" HIGH NONE	ORIGINAL RELEASE PCR R-00424	DIMENSIONS IN INCHES			
REV.	REV. BY	APPVD. BY	RELEASE	DESCRIPTION									SIZE B	DRAWING NO. 035-0032
REVISIONS														