



MODELS	1 3/8" THICK STYRENE		
CLOPAY/GALLERY	GD1SP, GR1SP	GD1LP, GR1LP	4132, 2132
HOLMES/ARTISTRY	AR1SP	AR1LP	6132
IDEAL/EXPRESSIONS	ED1SP	ED1LP	SFC38, MFC38
	SHORT PANEL	LONG PANEL	FLUSH

REV	DATE	ECO NUMBER	APPROVED	DESCRIPTION
00	10/15/07		SH	INITIAL RELEASE
01	01/31/12		SH	REVISED WIND SPEED TABLE FOR ASCE7-10.
02	03/29/17		SH	REVISED FOR 16'0" HIGH.
03	11/9/20		SH	UPDATED TITLE BLOCK AND REMOVED WIND CHART.




VERTICAL JAMB ATTACHMENT (C-90 BLOCK OR 2000 PSI MIN. CONCRETE COLUMN):
3/8"x4" SLEEVE ANCHORS ON 24" CENTERS (BOTH C-90 BLOCK OR 2000 PSI MIN. CONCRETE) OR 1/4"x4" TAPCON SCREWS ON 24" CENTERS (2000 PSI MIN. CONCRETE). WASHERS INCLUDED WITH SLEEVE ANCHORS. 1" O.D. WASHERS REQUIRED WITH TAPCONS. ANCHORS MAY BE COUNTERSUNK (BUT NOT REQUIRED) TO PROVIDE A FLUSH MOUNTING SURFACE. HORIZONTAL JAMBS DO NOT TRANSFER LOAD.

VERTICAL JAMB ATTACHMENT (WOOD FRAME BUILDINGS):
1/2"x3" LAG SCREWS ON 24" CENTERS. 1" O.D. WASHER REQUIRED. LAG SCREWS MAY BE COUNTERSUNK (BUT NOT REQUIRED) TO PROVIDE A FLUSH MOUNTING SURFACE. HORIZONTAL JAMBS DO NOT TRANSFER LOAD.

NOTE: TRACK CONFIGURATION ABOVE THE DOOR OPENING DOES NOT AFFECT THE WIND LOAD RATING OF THIS DOOR.

TRACK CONFIGURATION




HORIZONTAL TRACK SUPPORT BY DOOR INSTALLER (TO SUIT)



DOOR HEIGHT	"L"
6'-6"	70"
7'-0"	76"
7'-6"	82"
8'-0"	88"
8'-6"	94"
9'-0"	100"
9'-6"	106"
10'-0"	112"
10'-6"	118"
11'-0"	124"
11'-6"	130"
12'-0"	136"

DOOR HEIGHT	"L"
12'-6"	142"
13'-0"	148"
13'-6"	154"
14'-0"	160"
14'-6"	166"
15'-0"	172"
15'-6"	178"
16'-0"	184"

THE OPTIONAL GLAZING SHOWN ON THIS DRAWING MEETS THE WIND LOAD REQUIREMENTS OF THE FLORIDA BUILDING CODE OR INTERNATIONAL BUILDING CODE BUT DOES NOT MEET THE IMPACT RESISTANT REQUIREMENT FOR WINDBORNE DEBRIS REGIONS (REFER TO CHAPTER 16 FBC / IBC).



DESIGN ENGINEER: MARK WESTERFIELD, P.E.
FLORIDA P.E. #48495, NC P.E. #23832, TEXAS P.E. #91513

DESIGN LOADS: +20.0 P.S.F. & -21.0 P.S.F.
TEST LOADS: +30.0 P.S.F. & -31.5 P.S.F.

	CLOPAY CORPORATION 8585 DUKE BOULEVARD CINCINNATI, OH 45040 (513) 770-4800		MANUFACTURING PRODUCT CODE DSIE-1A471		WINDLOAD RATING W3		MAX. SIZE: 9'0" x 16'0"	
	DATE: 6/19/07		DRAWN BY: BFA		DESCRIPTION: GALLERY 1-3/8" EPS SC +20/-21 PSF		DRAWING NUMBER: 103952	
	CHECKED BY:		B		VER: IBC			
	Clopay Corporation All Rights Reserved.							