

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

Roof Deck Constructions

[See General Information for Roof Deck Constructions](#)


Construction No. 169

June 08, 2011

Uplift

Class 90

Fire Not Investigated



1. **Metal Roof Deck Panels*** — No. 26 MSG or No. 24 MSG min gauge coated steel. Panels continuous over two or more spans. End laps to occur over purlins with panels overlapped 6 in. with lap beginning 1 in. from purlin web and extending across purlin web. A bead of sealant may be used over panel end and side laps.

FABRAL INC ([View Classification](#)) — "Mighti-Rib".

METAL PANELS INC ([View Classification](#)) — "Strongseam R Panel"

2. **Panel Fasteners** — For panel to purlin connections, fasteners to be No. 12-14 by 1-1/2 in., self-drilling, self-tapping, hex-head, plated steel screws with a separate 1/2 in. OD coated steel washer, and a bonded neoprene sealing washer. Fasteners, used for panel to panel connections, to be No. 12 by 3/4 in. self-drilling, self-tapping, hex-head, plated steel screws with a separate 5/8 in. OD plated steel washer and a bonded neoprene sealing washer. **Spacing** — For panel to purlin fasteners, spacing to be in a 6-6-12-12-6-6 in. pattern with fasteners located 3 in. from the centerline on one side of each interior rib and both sides of each side rib. Spacing at end lap to be the same. Spacing at side laps to be 12 in. on center with a fastener located in line with the purlin fasteners.

3. **Insulation** — (Optional) — Any compressible blanket insulation 4 in. max thickness before compression.

4. **Purlins** — No. 16 MSG min gauge steel (min yield strength 50,000 psi).

5. **Lateral Bracing** — (Not shown) — As required.

Refer to General Information, Roof Deck Construction (Roofing Materials and Systems Directory) for items not evaluated.

*** Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.**

Last Updated on 2011-06-08

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."